

Cleco Power LLC

System Impact Study for Transmission Reservation Request

OASIS Request 72867499

The purpose of this study is to determine the availability of transfer capability across Cleco Power LLC's transmission system. This study will determine the ability to accommodate OASIS Request 72867499 for 250 MW of Yearly Firm Point to Point Transmission Service beginning January 1, 2011 through January 1, 2016.

This study was performed using the base case models identified in the table below. The studies were run using Siemens[®] PSS/e version 30 and MUST version 8.3 programs. Power flow models were developed to reflect anticipated operational conditions, including load, generation, extended outages and confirmed firm transactions, from January 1, 2011 through January 1, 2016.

Modifications to the base cases were made to reflect the latest information available. Changes that were made include the following:

1. Existing network resource generation in the source balancing authority was re-dispatched to allow for the transaction.
2. Customer's resources were re-dispatched to allow the transaction.
3. Cleco load was scaled to reflect the latest load forecast.
4. Confirmed firm transmission reservations were modeled for the year 2011 - 2016.
5. Active OASIS transmission service request with prior queue position were added.

If the flow on a monitored facility exceeds 100% of its emergency rating under normal and single contingency conditions with the transfer in place, the loading on the facility will be compared with the loading prior to the transfer. If the transfer causes an increase in flow greater than 3.0%, the facility is expected to require improvement.

Furthermore, if the transfer results in transmission bus voltage levels falling below criteria under single contingency conditions, then voltage support facility additions must be constructed.

With confirmed transactions, the ATC analysis indicates that the transaction is limited by the following facilities with an impact greater than 3.0%. These limiting elements must be upgraded to eliminate the transfer constraints they cause.

Study Results

ATC values were calculated for the study period and are listed below along with the limiting and contingency element. Due to the closely interconnected nature with neighboring systems, violations identified in directly interconnected transmission systems ("Affected System") will require an Affected System impact study with the identified Affected System(s) prior to the granting of transmission service. Identified Affected System: None

This study includes the following active OASIS transmission service requests with prior queue position:
71847922, 71956063, 72310136, 72616388, 72805097

Year	Limiting Element	Contingency Element	ATC (MW)
	None		

The following transmission bus voltage levels fall below planning criteria (0.92 p.u. under N-1) as a direct result of the transaction for certain single contingencies. Affected busses and their worst offending single contingency are provided below.

Year	Bus Voltage Violations	Contingency Element	Bus Voltage (P.U.)
	None		

Upgrade Cost Estimates

Upgrade cost estimates are planning estimates for transmission facilities owned by Cleco and are listed below.

A facility study will provide detailed cost estimates and solutions for the required upgrades on the limiting elements. Facility study results may be different due to transmission system configuration changes and/or prior OASIS requests in the facilities study phase. Facilities owned by others will require a system impact study and a facility study to obtain estimates of costs of required upgrades on the systems owned by others.

Limiting Elements	Planning Estimate for Upgrade	Year Needed
No Cleco Limiting Element		

Summary of System Impact Study Results:

OASIS Request	Period	Cases Used	Capacity (MW)	ATC Available
72867499	January 1, 2011- January 1, 2016	2011 Summer Peak 2011 Winter Peak 2014 Summer Peak 2014 Winter Peak 2016 Summer Peak	250	Yes

The requested transfer capability is available for the transactions specified in the study as stated below,

OASIS Request 72867499: January 1, 2011 through January 1, 2016 250 MW
Total: 250 MW

These results are based upon the most recent information available at the time of the study. TTC and ATC values obtained in the study are for Cleco Power's transmission system and are subject to change as a result of any modifications to the assumptions utilized in the study.