



Entergy Services, Inc.
Mail Unit L-ENT-24A
639 Loyola Avenue
New Orleans, LA 70113
Tel 504-576-4993
Fax 504-576-5123
e-Mail gpierc2@entergy.com

Greg Pierce
Director Transmission Compliance

March 17, 2009

VIA ELECTRONIC FILING

Kimberly D. Bose, Secretary
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426

Re: Entergy Services, Inc.; Docket No. ER05-1065-000
Report of AFC-Related Errors

Dear Secretary Bose:

Pursuant to the Federal Energy Regulatory Commission's ("Commission") April 24, 2006 Order in *Entergy Services, Inc.*, 115 FERC ¶ 61,095 (2006) ("April 24 Order"), Entergy Services, Inc., acting as agent for the Entergy Operating Companies,¹ hereby notifies the Commission it has recently become aware of the following AFC-related error.

In the April 24 Order, the Commission conditionally accepted Entergy's proposal to establish an Independent Coordinator of Transmission ("ICT") for the Entergy System. As the Commission is aware, the Southwest Power Pool, Inc. acts as Entergy's ICT. In the April 24 Order, the Commission imposed an obligation for Entergy to "notify the Commission, the ICT and the Users Group within 15 days if Entergy discovers that it has lost data, or reported inaccurate data, or otherwise believes that it has mismanaged data." See April 24 Order at P 110. Accordingly, Entergy submits the following explanation of recently discovered issue involving inaccurate outage data in RFCALC.

¹ The Entergy Operating Companies include: Entergy Arkansas, Inc., Entergy Gulf States Louisiana, LLC, Entergy Louisiana, LLC, Entergy Mississippi, Inc., Entergy New Orleans, Inc., and Entergy Texas, Inc. The Entergy Operating Companies and Entergy Services, Inc. are referred to collectively herein as "Entergy."

Kimberly D. Bose, Secretary

Page 2

State Estimator Savecase

On March 3, 2009 at approximately 2:25 AM, while attempting to retrieve a historical “savecase” into a study application, a Transmission Operator inadvertently retrieved the “savecase” into State Estimator, which RFCALC utilizes to calculate AFC values. The “savecase” data was corrected at approximately 3:10 AM and RFCALC ran with the correct information at 4:15AM.

During the period that the incorrect “savecase” was in place, five TSRs were processed. The TSRs were all confirmed.

In the event that further information is needed, please do not hesitate to contact the undersigned.

Respectfully submitted,
/s/Gregory D. Pierce
Gregory D. Pierce
Director, Transmission Compliance

cc: Southwest Power Pool, Inc.
ICT Users Group
Service List; Docket No. ER05-1065-000

CERTIFICATE OF SERVICE

I hereby certify that I have this 17th day of March, 2009, served the foregoing document upon the Southwest Power Pool, Inc., the ICT Users Group, and each person designated on the official service list compiled by the Secretary in this proceeding.

/s/ Nicole A. Livaccari

Nicole A. Livaccari
Mail Unit L-ENT-24A
New Orleans, LA 70113
Tel: (504) 576-4296