



Entergy Services, Inc.
Mail Unit L-ENT-24A
639 Loyola Avenue
New Orleans, LA 70113
Tel 504-576-4993
Fax 504-576-5123
e-Mail gpierc2@entergy.com

Gregory D. Pierce
Director Transmission Compliance

December 27, 2011

VIA ELECTRONIC FILING

Kimberly D. Bose, Secretary
Federal Energy Regulatory Commission
888 First Street, N.E.
Washington, D.C. 20426

Re: Entergy Services, Inc.; Docket No. ER05-1065-000
Report of AFC-Related Errors

Dear Secretary Bose:

Pursuant to the Federal Energy Regulatory Commission's ("Commission") April 24, 2006 Order in *Entergy Services, Inc.*, 115 FERC ¶ 61,095 (2006) ("April 24 Order"), Entergy Services, Inc., acting as agent for the Entergy Operating Companies,¹ hereby notifies the Commission it has recently become aware of the following AFC-related error.

In the April 24 Order, the Commission conditionally accepted Entergy's proposal to establish an Independent Coordinator of Transmission ("ICT") for the Entergy System. As the Commission is aware, the Southwest Power Pool, Inc. acts as Entergy's ICT. In the April 24 Order, the Commission imposed an obligation for Entergy to "notify the Commission, the ICT and the Users Group within 15 days if Entergy discovers that it has lost data, or reported inaccurate data, or otherwise believes that it has mismanaged data." See April 24 Order at P 110. Accordingly, Entergy submits the following summary of mismanaged data.

¹ The Entergy Operating Companies include: Entergy Arkansas, Inc., Entergy Gulf States Louisiana, LLC, Entergy Louisiana, LLC, Entergy Mississippi, Inc., Entergy New Orleans, Inc., and Entergy Texas, Inc. The Entergy Operating Companies and Entergy Services, Inc. are referred to collectively herein as "Entergy."

Kimberly D. Bose, Secretary
December 27, 2011
Page 2

EMS Network Model

On December 13, 2011, the ICT identified that the newly constructed 230 KV Coly-Hammond line was showing out of service in the AFC models for the Planning and Study Horizons. Entergy determined that the line was put in service December 8, 2011 at approximately 20:00 and the outage associated with this work continued to exist in AFC models. The EMS Network model was corrected for the Operating and Planning Horizons on December 13, 2011 at 17:20 by manually removing the outage in the AFC process. The Study Horizon model, which is normally updated twice a month, was correct for the December 7, 2011 update and then was updated as scheduled on December 15, 2011 which removed the outage.

While modeling the line out of service may have resulted in incorrect AFC values, it is not technically feasible to determine the exact impact on AFCs. Additionally, Transmission Service Requests (TSRs) processed during the time the error existed could have resulted in incorrectly granting or denying service. This issue could have potentially affected customers requesting service in the Operating and Planning Horizons.

In the event that further information is needed, please do not hesitate to contact the undersigned.

Respectfully submitted,
/s/Gregory D. Pierce
Gregory D. Pierce
Director, Transmission Compliance

cc: Southwest Power Pool, Inc.
ICT Users Group
Service List; Docket No. ER05-1065-000

CERTIFICATE OF SERVICE

I hereby certify that I have this 27th day of December, 2011, served the foregoing document upon the Southwest Power Pool, Inc., the ICT Users Group, and each person designated on the official service list compiled by the Secretary in this proceeding.

/s/ Nicole A. Livaccari

Nicole A. Livaccari
Mail Unit L-ENT-24A
New Orleans, LA 70113
Tel: (504) 576-4296