Progress Energy

August 19, 2010

VIA ELECTRONIC FILING

Ms. Ann Cole, Commission Clerk
Florida Public Service Commission
2540 Shumard Oak Boulevard
Tallahassee, FL 32399-0850

Re: Summary of Pasco County Resource Recovery Event on August 18, 2010; Undocketed

Dear Ms. Cole:

Pursuant to FPSC Rule 25-17.086, F.A.C., "Periods During Which Purchases are Not Required", Progress Energy Florida (PEF) is providing notice to the Florida Public Service Commission that PEF had to take Pasco County Resource Recovery (PCRR) off-line at 10:46 on 08/18/10. This action was taken due to the fact the pilot wire protective relay was disabled due to a problem at PCRR equipment.

The event began at 10:15 hours on 08/18/10 when a PEF relay tech verified that there was no primary line protection on the Hudson-Pasco Resource Recovery 115 kV line. Once this problem was confirmed, the PEF Supervisor called PCRR to come off-line immediately. PCRR informed PEF ECC that the unit will be off-line in 15 minutes. The PEF supervisor informed PCRR that once the unit was off, the 115kV line will be opened. PEF also notified the FRCC Reliability Coordinator of the event.

On 08/19/2010 at around 12:12 PM, PEF ECC received word that the pilot wire protective relaying was repaired on the Hudson-Pasco Resource Recovery 115 kV line. At 12:41 PM the Hudson-Pasco Resource Recovery 115 kV line was placed back in service. At 13:20 PM PCRR was back on-line.

Thank you for your assistance in this matter. Should you have any questions, please feel free to call me at (727) 820-5184.

Sincerely,

John T. Burnett lms

John T. Burnett

JTB/lms