

**Idaho Power ATC Adjustment Log**  
This log is used to reflect actions that occurred to correct ATC

Date ATC Corrected	Description of Action that Resulted in inadvertently posting incorrect ATC	Impacted Path	Time Period Impacted
5/22/2007	An outage was marked completed on the system. However, the system incorrectly reverted to the winter operating TTC for the impacted paths, ignoring another outage that was posted for later in the month that would reduce the available TTC once again. This resulted in ATC being posted for days in June as available that was not really available due to the upcoming outage. It also resulted in days not impacted by the posted outage, reflecting ATC based on different operating season TTC.	LaGrande In, LaGrande Out, Northwest-Idaho, Idaho-Northwest	Jun-07
5/24/2007	A portion of native load was inadvertently accounted for twice resulting in incorrectly decrementing ATC on Lagrande by 9 to 11 MW depending on the month. This impacted ST Firm ATC.	LaGrande In	June 2007 - Dec 2008
5/24/2007	Yearly Firm ATC on LaGrande was incorrectly posting 48MW available. The error was due to an incorrect network load number in the long-term horizon. This was corrected and reduced the available LT Firm ATC to the correct value which should have reflected no available LT Firm ATC on LaGrande.	LaGrande In, Northwest-Idaho	Jan 2009 - Jan 2010
6/20/2007	A network customer's allocated monthly set-aside was incorrectly reduced by 4MW which resulted in 4MW firm capacity being posted for the month of July in error.	ENPR In, LOLO in	Jul-07
6/27/2007	An error was discovered in the committed use calculation that resulted in additional MW (up to 10) being posted as available firm capacity that was not available. Initial incorrect posting occurred in the afternoon on 6/25/06.	ENPR In, LOLO in	Feb 2008 - May 2008
7/10/2007	After a OATI software upgrade some Set Asides were not calculating into the ATC calculation thus releasing ATC on the OASIS.	ENPR In, LOLO In, LAGRANDE In, HTSP In	2007-2008-2009
8/7/2007	The daily and hourly non firm was not released at the 11:00 AM initialization due to a OATI sytem problem. Was corrected at 11:45 AM.	ENPR, LOLO, LAGRANDE	AUG 8th-2007
12/17/2007	Monthly firm ATC was incorrectly posting. Idaho Power has been incorporating the recently received network resource forecasts into its ATC calculation on its system. In the process of updating all the various components used in the OATI system to account for the use of these resources, ATC was reflecting incorrect capacity on the OASIS website. Capacity was being reported for April 2008 - July 2008 across Brownlee East/Idaho Northwest in error.	LOLO, ENPR	Apr 2008 - July 2008