

June 30, 2006

Draft

LADWP

# Available Transfer Capability Methodology

The Los Angeles Department of Water and Power (LADWP) determines the Available Transfer Capability (ATC) on its electrical transmission system in a manner that allows for maximum reliable utilization of the transmission system after accounting for LADWP's Committed Uses. These Committed Uses consist of transmission capability needed to meet (i) the current and reasonably forecasted load of its native load customers, (ii) LADWP's obligations to maintain Operating Reserves and Replacement Reserves under the Western Electricity Coordinating Council's (WECC's) Minimum Operating Reliability Criteria, (iii) LADWP's existing contractual obligations to its transmission service customers, and (iv) the connectivity needs of LADWP's out-of-state generation resources.

LADWP will calculate Total Transmission Capability (TTC) and ATC using methods consistent with good utility practice and with the WECC's publicly-available "Determination of Available Transfer Capability within the Western Interconnection."