



**Public Service Company of Colorado  
Control Area and Transmission Provider**

April 9, 2007

PSCo has now modified its Tag Validation to use “Path POR/POD” validation instead of “POR/POD” validation. This allows Customers to use the same TSR # on more than one line in the tag and the validation checks the first POR and the last POD to ensure that the tag matches up with the TSR.

In the case of the Four Corners Bus, this allows a Customer to tag the Physical Path as follows, with one TSR # 1234567 for FOURCORNE345-PSCO.

CA	TP	PSE	POR	POD	Sched Entities	TSR #
AZPS		PSE01	Source: FOURCORNE345			
	PSCO	PSE01	FOURCORNE345	FOURCORNE345	AZPS	1234567
	PSCO	PSE02	FOURCORNE345	SJ345	PNM	1234567
	PSCO	PSE02	SJ345	RFL	WACM	1234567
	PSCO	PSE02	RFL	PSCO	PSCO	1234567
PSCO			Sink: PSCO-CA-Default			

This method is consistent with the Western Interchange Tool (WIT) tagging rules as well as the Western Electricity Coordinating Council (WECC) Business Practices 7.3 and 7.4.