

**Public Service Company of Colorado (PSCo)
TRM Updates**

PSCo updates the TTC values related to TRM at least twice a year when the Western Electricity Council (WECC) Operating Transfer Capability (OTC) Policy Committee approves new seasonal path ratings. These new TTCs take effect on June 1 (Summer Season) and on November 1 (Winter Season). Revised TTC values impact the TRM calculated for the appropriate paths and the TRM is updated at the same time. TRM and TTC values are also revised and reposted at other times as path or line ratings are updated or adjusted for system conditions. PSCo does not make use of CBM.

Table 1

January 1, 2010
(Revised due to Comanche 3)

2009-10 Winter (January 1 – May 31)

PSCo Central System to Midway

(System Intact)

DPSN - DPSS: TTC =9999 (not constrained), TRM=157 (delivery to RMRG)

DPSS - FULLER: TTC=9999 (not constrained), TRM=157 (delivery to RMRG)

FULLER - MIDW: TTC=9999 (not constrained), TRM=157 (delivery to RMRG)

Midway to PSCo Central System

(System Intact)

MIDW - FULLER: TTC=1280, TRM=46 (RMRG to PSCo deliveries)

FULLER - DPSS: TTC=1280, TRM=46 (RMRG to PSCo deliveries)

DPSS - DPSN: TTC =1280, TRM=46 (RMRG to PSCo deliveries)

TOT 7 (North to South)

(System Intact)

AU - TOT7N: TTC=516, TRM=46 (RMRG to PSCo deliveries)

TOT7N - TOT7S: TTC=516, TRM=46 (RMRG to PSCo deliveries)

TOT7S - PSCO: TTC=516, TRM=46 (RMRG to PSCo deliveries)

TOT 7 (South to North)

(System Intact)

PSCO - TOT7S: TTC=884, TRM=184 (delivery to RMRG)

TOT7S - TOT7N: TTC=884, TRM=184 (delivery to RMRG)

TOT7N - AU: TTC=884, TRM=184 (delivery to RMRG)

PSCo to Story:

(System Intact)

PSCO - PAWN: TTC=1300, TRM=86 (delivery to RMRG)

PAWN - STY: TTC=662, TRM=86 (delivery to RMRG)

Story to PSCo:

(System Intact)

STY - PAWN: TTC=662, TRM=92 (RMRG delivery to PSCo)

PAWN - PSCO: TTC=1300, TRM=92 (RMRG delivery to PSCo)