

UNITED STATES OF AMERICA
BEFORE THE
FEDERAL ENERGY REGULATORY COMMISSION

Puget Sound Energy, Inc.

)

Docket No. ER11-____-000

PREPARED DIRECT TESTIMONY OF
LLOYD C. REED
ON BEHALF OF PUGET SOUND ENERGY, INC.

1 **SECTION I - INTRODUCTION**

2 **Q. Please state your name and business address.**

3 A. Lloyd C. Reed, 10025 Heatherwood Lane, Highlands Ranch, Colorado 80126.

4 **Q. By whom and in what capacity are you employed?**

5 A. I am the President of Reed Consulting, an independent energy consulting organization. I
6 have been retained by Puget Sound Energy, Inc. ("PSE") to assist PSE staff with the
7 development of revisions to Schedule 13 to PSE's Open Access Transmission Tariff
8 ("OATT").

9 **Q. Please describe your educational background and professional experience.**

10 A. I graduated from the University of Washington with a degree of Bachelor of Science,
11 Electrical Engineering in 1982. I have over twenty-five years experience in the Western
12 Energy Coordinating Council ("WECC") energy markets in the areas of power marketing
13 and trading, power systems operations, power portfolio risk management, renewable
14 resource analysis, power contract negotiation and administration, and regulatory affairs.

15 **Q. Are you familiar with how PSE in particular manages loads and resources within its
16 Balancing Authority Area ("BAA")?**

1 A. Yes. My background experience includes nearly two decades as an employee of PSE,
2 serving in various positions of responsibility for operation and management of PSE's
3 generation resources. Between 1982 and 1984, as an employee of PSE, I conducted
4 multiple resource planning studies that were utilized in determining the operation of
5 PSE's hydroelectric, coal, and natural-gas fired generating plants. Between 1984 and
6 1993, I was PSE's power scheduler/short-term marketer and my duties included
7 developing daily load forecasts for the PSE BAA, determining the pre-scheduled dispatch
8 points of all of PSE's generating resources, and implementing short-term wholesale
9 power purchase and sales transactions with various counterparties. In addition, between
10 1999 and 2001, I was PSE's Director of Power Operations, with responsibilities that
11 included managing all of PSE's real-time, day-ahead and short-term (up to one year)
12 power operations functions.

13 **Q. Are you familiar with the impacts of wind generation in the PSE BAA?**

14 A. Yes. Acting as an independent consultant to PSE, I conducted a series of studies between
15 2003 and 2007 regarding the short-term operational impacts and associated costs of
16 integrating the variable output of wind plants into PSE's BAA. These studies focused on
17 the hour-ahead and day-ahead impacts of wind generation, and how PSE might manage
18 wind generation variability. The results of these studies were utilized by PSE in its
19 integrated resource planning process and by PSE's resource acquisition group in its
20 acquisition of two large-scale wind projects. Various analytical tools that I originally
21 developed have also been utilized by PSE operations personnel to help quantify the
22 amount of flexible capacity that PSE must maintain in order for it to manage its existing
23 wind generation.

3 A. Yes. I previously provided testimony in support of PSE's Schedule 12 filing, which was
4 submitted to the Commission on June 14, 2010 in Docket No. ER10-1436. In its
5 Schedule 12 filing, PSE proposed to provide within-the-hour Following Capacity service
6 to wind plants located within its BAA. The Commission rejected that filing in an order
7 issued on August 13, 2010, because the proposed rate was based on the capacity cost of a
8 proxy unit which, the Commission found, had not been shown to be a reasonably accurate
9 representation of the costs incurred in providing a following service to wind resources.¹

10 Q. Did PSE consult with FERC Staff after the close of proceedings in Docket No.
11 ER10-1436?

12 A. Yes. FERC Staff expressed the view that supplying the within-the-hour capacity needed
13 to balance the output of wind plants in a utility's BAA is a component of Regulation and
14 Frequency Response Service and not a separate following capacity service. FERC Staff
15 suggested that the cost of supplying such intra-hour capacity should be recovered through
16 a utility's generator regulation and frequency response ancillary service schedule in the
17 manner approved by the Commission in *Westar Energy, Inc.*, 130 FERC ¶ 61,215 (2010).

18 Q. What is the purpose of your testimony in this docket?

19 A. Building on the FERC Staff's guidance, PSE has asked me to recalculate the Schedule
20 13, Regulation and Frequency Response Service purchase obligation of wind and other
21 non-dispatchable generation resources (hereinafter referred to as "Intermittent Purchase
22 Obligation") that export energy out of PSE's BAA in a manner consistent with that
23 recently approved by the Commission in *Westar Energy, Inc.*, Docket No. ER09-1273.

¹Puget Sound Energy, Inc., 132 FERC ¶ 61,128 (2010).

Q. In addition to your testimony, is PSE submitting other testimony with the Commission regarding updates to Schedules 3 and 13?

3 A. Yes. In addition to my testimony regarding the recalculation of the Schedule 13
4 Intermittent Purchase Obligation, PSE also proposes in this filing to update its cost of
5 service for regulation under Schedules 3 and 13 of its OATT and is submitting additional
6 testimony in support thereof. First, in the testimony of Mr. Michael Tongue, Mr. Tongue
7 describes the set of PSE generating resources that are utilized and capable of providing
8 within-the-hour regulation service. Second, in the testimony of Mr. Charles Olson, Mr.
9 Olson computes an updated PSE return on equity for use in updating the regulation rate
10 under Schedules 3 and 13. Third, the testimony of Mr. Jim Sant will describe the capital
11 structure, cost of long term debt, and overall rate of return to be used in calculating the
12 updated regulation rates under Schedules 3 and 13. Finally, in the testimony of Mr. John
13 Story, Mr. Story determines PSE's capacity-related costs of supplying within-the-hour
14 regulation service, based upon the pool of resources identified by Mr. Tongue and the
15 rate of return as computed by Mssrs. Olson and Sant.

16 Q. Why is PSE implementing a revised purchase obligation for wind and other
17 intermittent resources under Schedule 13?

18 A. PSE provides Regulation and Frequency Response Service under Schedules 3 and 13 by
19 constantly maintaining an amount of flexible generating capacity that can be utilized to
20 manage the variability of load and generation. The regulation purchase obligation
21 specified in PSE's current Schedule 13 (2.00%) for all exporting generators, dispatchable
22 or otherwise, was developed in 1998 and was based on 1996 historical conditions. PSE
23 did not have any wind generation within its BAA at the time the 2.00% regulation

1 purchase obligation was derived. However, following the addition of wind generation
2 into the PSE BAA beginning in 2006, PSE has determined that the existing 2.00%
3 regulation purchase obligation is not representative of the actual amounts of capacity that
4 PSE must set aside on average each hour in order to manage the within-the-hour
5 scheduled versus actual generation deviations of intermittent generating resources such as
6 wind.

7 **Q. Based on your analysis, how much regulation capacity should wind and other
8 intermittent resources be required to purchase under Schedule 13 to accurately
9 reflect the amount of capacity that PSE must set aside in order to manage the
10 within-the-hour deviations of intermittent generating resources?**

11 A. Following the approach approved by the Commission in *Westar*, I compared historical
12 scheduling and forecast data of the wind generation in PSE's BAA to actual output to
13 determine the regulation capacity needed to balance deviations in wind output within the
14 hour. I then performed a portfolio-wide analysis, consistent with *Westar*, to give wind
15 generation the benefit of any offsetting variability from load and dispatchable generation
16 resources. As the analysis in Section III of my testimony demonstrates, based on their
17 proportionate effect on system variability (and accounting for the effect of diversity
18 benefits), transmission customers exporting energy outside the PSE BAA from wind and
19 other intermittent resources located in the PSE BAA should be required purchase an
20 amount of Generator Regulation and Frequency Response Service equal to 16.77% rather
21 than the 2.00% currently required for all exporting generators. The revised Intermittent
22 Purchase Obligation of 16.77% will allow PSE to recover a greater portion of its actual
23 cost of supplying regulation capacity to the exporting wind plants located within its BAA

1 from the exporting wind plants responsible for such costs. In addition, the revised
2 Intermittent Purchase Obligation will allow PSE to recover costs that are commensurate
3 with an exporting wind plant's proportionate impact on net system variability while also
4 taking into account the diversity benefits between within-the-hour variations in loads,
5 wind resource generation, and dispatchable resource generation.

6 **SECTION II - OPERATIONAL CHARACTERISTICS OF PSE'S WIND PLANTS,
7 BALANCING AUTHORITY AREA LOADS, AND
8 DISPATCHABLE GENERATING PLANTS**

9

10 **Q. Please describe the operational characteristics of wind generation.**

11 A. In general, the generation output of wind plants is intermittent and highly variable in
12 nature. Since wind plants do not have any storage capability beyond the rotational inertia
13 of the turbine apparatus, real-time power output is directly a function of the wind speed at
14 any given point in time. Therefore, the generation output of a wind plant can vary
15 considerably from hour to hour and even within the same hour. For example, on
16 November 27, 2009, the generation output at PSE's Wild Horse plant was 0 MW halfway
17 through the 0300 scheduling hour, it rose to 175 MW halfway through the 0400 hour, and
18 dropped back to 26 MW halfway through the 0500 hour. Within the 0400 hour alone, the
19 Wild Horse plant had both a 109 MW increasing generation ramping event and a 100
20 MW decreasing generation ramping event. Forecasting these kinds of wind generation
21 ramping events is much more difficult than forecasting load ramping events, since PSE's
22 BAA loads tend to follow established hourly customer usage patterns whereas wind
23 generation on PSE's system displays a higher degree of randomness.

24 **Q. Can the output of wind plants be dispatched like conventional thermal or
25 hydroelectric plants?**

1 A. No. Unlike conventional thermal and hydro plants, the output of a wind plant cannot be
2 dispatched to operate at a specified, pre-determined generation level. It is physically
3 possible to limit the output of a wind plant to a specified maximum generation value;
4 however, the plant's real-time generation output would still be highly variable, and
5 therefore unpredictable, at generation levels below the specified maximum limit.

6 Q. Does PSE have any operational experience with wind plants?

7 A. Yes. PSE currently owns and operates 480 MW of generation capacity from three
8 operating wind farms. PSE began receiving the entire output of the 150 MW Hopkins
9 Ridge wind plant, located in eastern Washington State, in late 2005. In the fall of 2008,
10 PSE completed its Hopkins Ridge Expansion project and began receiving an additional 7
11 MW of added capacity. PSE began receiving the entire output of the 229 MW Wild
12 Horse wind plant, located in central Washington State, in late 2006. In November 2009,
13 PSE completed its Wild Horse Expansion project and began receiving an additional 44
14 MW of added capacity. PSE also has a long term power purchase agreement with an
15 independent power producer for 50 MW of wind capacity from the 221 MW Klondike III
16 wind farm located in eastern Oregon that commenced deliveries in December 2007. PSE
17 is also in the process of constructing Phase I of its Lower Snake River (“LSR”) wind
18 project, located in eastern Washington State. 350 MW of new wind capacity from the
19 LSR project is expected to enter commercial operation during the second quarter of 2012.

20 O. Are all of the PSE wind plants you mentioned above located within PSE's BAA?

21 A. Currently, only the Wild Horse plant is located within the PSE BAA. Both the Hopkins
22 Ridge plant and the Klondike III plant are located within the Bonneville Power
23 Administration’s (“BPA”) BAA; BPA provides BAA services, including within-the-hour

1 Regulation Capacity services, for Hopkins Ridge and PSE's purchased share of Klondike
2 III.

3 **Q. Are there any wind plants located within the PSE BAA that are not owned or
4 operated by PSE?**

5 A. Yes. Invenergy Wind North America LLC's ("Invenergy") 96 MW Vantage Wind
6 Energy LLC ("Vantage") plant. The entire output of the Vantage plant is exported out of
7 the PSE BAA and delivered to a third-party purchaser located in California pursuant to a
8 long-term transmission agreement. The Vantage plant went into commercial operation on
9 October 4, 2010.

10 **Q. What type of historical generation data is available for the wind plants located
11 within the PSE BAA?**

12 A. PSE has detailed, 4-second interval actual generation records for the Wild Horse plant
13 extending back to when the plant first began generating test energy in 2006. PSE
14 personnel aggregated the base 4-second interval data into 1-minute interval data, and the
15 1-minute data was provided to me. I subsequently verified and re-aggregated the 1-
16 minute data into 10-minute interval data for use in determining the Schedule 13
17 Intermittent Purchase Obligation. A complete dataset of Wild Horse 1-minute interval
18 and 10-minute interval generation for calendar year 2010 is contained in Table 1 of my
19 confidential workpapers. I also examined Wild Horse generation data from calendar
20 years 2008 and 2009 and I noted that the within-the-hour variability of the Wild Horse
21 plant during these prior years was very similar to the variability that I observed for
22 calendar year 2010. In addition to the Wild Horse generation data, PSE has available 4-
23 second interval generation data for the Vantage plant extending back to when the plant

1 began generating test energy in mid-2010. PSE personnel aggregated the base 4-second
2 interval data into 1-minute interval data, and the 1-minute data was provided to me for
3 the period of time during calendar year 2010 that the plant was in commercial operation
4 (October 4, 2010- December 31, 2010). I subsequently verified and re-aggregated the 1-
5 minute data into 10-minute interval data for use in determining the Schedule 13
6 Intermittent Purchase Obligation. A complete dataset of Vantage 1-minute interval and
7 10-minute interval generation for the period October 4, 2010 – December 31, 2010 is
8 contained in Table 1 of my confidential workpapers.

9 **Q. Do the Wild Horse and Vantage wind plants generally exhibit similar generation
10 patterns?**

11 A. Yes. The Wild Horse and Vantage plants are both located approximately 75 miles east of
12 Seattle, Washington and the two plants are physically adjacent to each other. So while
13 the Vantage plant has only been in commercial operation since October 4, 2010, it is
14 possible to determine the Schedule 13 Intermittent Purchase Obligation across a longer
15 time period – for instance a full calendar year - since the generation patterns of the
16 Vantage plant in time periods prior to its commercial in service date would be similar to
17 the generation patterns of the Wild Horse plant. Therefore, as I explain in more detail
18 later in my testimony, the computation of the updated Schedule 13 Intermittent Purchase
19 Obligation utilizes Wild Horse generation data for the period January 1, 2010 through
20 October 3, 2010, and the combination of Wild Horse and Vantage generation data for the
21 period October 4, 2010 through December 31, 2010.

22 **Q. What type of generation forecast data did you utilize for the Wild Horse and
23 Vantage plants in determining the Schedule 13 Intermittent Purchase Obligation?**

1 A. I utilized 60-minute before the hour persistence forecasts for both the Wild Horse and
2 Vantage plants in the determination of the Intermittent Purchase Obligation. I also
3 examined Wild Horse 60-minute persistence forecasts based upon calendar year 2008 and
4 2009 actual generation data, and I noted that the accuracy of the forecasts in these prior
5 years was very similar to the accuracy of the forecasts that I observed for calendar year
6 2010.

7 **Q. Is it reasonable to utilize 60-minute persistence-based forecasts in the determination**
8 **of the Schedule 13 Intermittent Purchase Obligation?**

9 A. Yes. First of all, I analyzed the forecast accuracy of the Vantage plant across the time
10 period that the plant was in commercial operation during calendar year 2010, based upon
11 the next-hour transmission schedules that were submitted to PSE and the plant's actual
12 generation during that corresponding hour. I found that the accuracy of the Vantage
13 plant's hour-ahead forecasts, as represented by their hourly submitted transmission
14 schedules, were significantly worse than 60-minute persistence. Therefore, utilizing 60-
15 minute persistence forecasts for the Vantage plant as opposed to using the actual hour-
16 ahead transmission schedules is a reasonable and conservative assumption that, in turn,
17 acts to reduce the computed Intermittent Purchase Obligation. In the case of the Wild
18 Horse plant, since this plant is located within the PSE BAA hourly delivery schedules are
19 not created for the plant. This treatment is identical to how PSE's dispatchable generation
20 plants located within the PSE BAA are managed. For internal power management and
21 system balancing purposes to meet load-service obligations, PSE does create both day-
22 ahead and real-time Wild Horse generation forecasts using the 3Tier forecasting system.
23 However not all of the hour-ahead forecasts are retained by PSE. Therefore, utilizing 60-

1 minute persistence is also a reasonable approach in determining hour-ahead generation
2 forecasts for the Wild Horse plant, and this approach is consistent with the treatment of
3 the Vantage plant.

4 **Q. Is the use of 60-minute before the hour persistence forecasts in the determination of
5 the Schedule 13 Intermittent Purchase Obligation consistent with the market
6 structure in the Pacific Northwest?**

7 A. Yes. Currently, the Pacific Northwest market utilizes an hourly scheduling interval with
8 schedules for the upcoming hour generally being finalized with BAA operators 20-30
9 minutes prior to the start of the hour. However, additional time is needed for operators of
10 wind plants and the BAA's provider of balancing services to: (1) evaluate recent and
11 current wind generation patterns, (2) develop next hour generation forecasts, (3) factor in
12 these forecasts into their operation plans, (4) adjust market positions to establish
13 necessary flexibility on internal generation for the next hour, and (5) communicate their
14 next-hour generation schedules to their purchasing counterparties and transmission
15 providers and to create the associated scheduling tags. Using 60-minute before the hour
16 persistence forecasts in the determination of the Schedule 13 Intermittent Purchase
17 Obligation is therefore reasonable and is consistent with current regional scheduling
18 practices.

19 **Q. Can the datasets of Wild Horse and Vantage actual generation and forecasted
20 generation be utilized to determine the expected value of the within-the-hour
21 forecast generation versus actual generation of both of the wind plants located
22 within the PSE BAA?**

1 A. Yes. By comparing the forecasted hour-ahead generation against the actual real-time
2 generation, one can assess the within-the-hour variability that PSE's system must account
3 for and determine, using statistical measures, the expected amount of deviation between
4 forecast and actual generation exhibited by the two existing wind plants located within
5 PSE's BAA. The hour-ahead forecasts represent the most accurate forecasts available
6 before the start of each scheduling hour; therefore, this set of forecasts was utilized in my
7 evaluation rather than day-ahead forecasts. Also, as I describe later in my testimony, the
8 hour-ahead wind generation forecasts were adjusted to reflect generation ramping
9 impacts in order to create a "best available" forecast.

10 **Q. What type of historical load data is available for the PSE BAA loads?**

11 A. PSE has detailed, 4-second interval actual BAA load records extending back for several
12 years. PSE personnel aggregated the base 4-second interval data into 1-minute interval
13 data for calendar year 2010, and the 1-minute data was provided to me. I subsequently
14 verified and re-aggregated the 1-minute data into 10-minute interval data for use in the
15 Schedule 13 Intermittent Purchase Obligation studies. A complete dataset of the 1-minute
16 interval and 10-minute interval PSE BAA loads for calendar year 2010 is contained in
17 Table 2 of my confidential workpapers. I also examined PSE BAA load data from
18 calendar years 2008 and 2009, and I noted that the within-the-hour variability of PSE's
19 loads during these prior years was very similar to the variability that I observed for
20 calendar year 2010.

21 **Q. Does PSE's BAA load exhibit significant variability?**

1 A. Yes. The majority of PSE's BAA load consists of customers whose power usage is
2 variable depending upon short-term weather trends. PSE's loads are most variable in the
3 Winter Season and are least variable in the Summer Season.

4 **Q. Does the short-term variability of wind generation located within the PSE BAA
5 match up with the short-term variability of PSE's BAA load?**

6 A. Generally speaking, no. The short-term variability in generation output at the Wild Horse
7 and Vantage wind plants is not highly correlated with the variability of PSE's BAA load.
8 This situation occurs since the wind plant generation output is most highly dependent
9 upon wind speed impacts while PSE's BAA load is most highly dependent upon
10 temperature impacts. Also, the two wind plants within the PSE BAA are located
11 approximately 75 miles away from PSE's load center in the Puget Sound region, across a
12 mountain pass, and the prevailing weather patterns at the wind plant sites can be quite
13 different from the weather in the Puget Sound area.

14 **Q. Do the non-wind generation plants located within the PSE BAA exhibit significant
15 short-term variability?**

16 A. In general, no. PSE's non-wind generating plants - which I collectively refer to as
17 Dispatchable Plants - exhibit very little deviation between their scheduled output and
18 their actual output. The two situations where the Dispatchable Plants may exhibit higher
19 levels of within-the-hour variability are: (1) the case where a plant is intentionally
20 ramped up or down in response to PSE's dispatch signal, or (2) the case where a plant
21 endures a forced outage event that restricts the plant's generation output. However, as I
22 explain later in my testimony, the two sources deviations noted above are not included in
23 the determination of PSE's within-the-hour regulation requirement since in the first case

1 the generation variations are not caused by random fluctuations, and in the second case
2 the variations can be managed via PSE's contingency reserves.

3 **Q. Does the short-term variability of the Dispatchable Plants located within the PSE**
4 **BAA match up with the short-term variability of PSE's BAA load and/or wind**
5 **generation?**

6 A. No. Disregarding intentional ramping operations, the scheduled versus actual generation
7 deviations on the Dispatchable Plants are primarily random in nature and these deviations
8 have a low correlation to within-the-hour load deviations and within-the-hour wind
9 generation deviations.

10 **Q. What type of historical generation data is available for the Dispatchable Plants**
11 **located within the PSE BAA?**

12 A. PSE has detailed, 4-second interval generation records for its Dispatchable Plants
13 extending back for several years. PSE personnel aggregated the base 4-second interval
14 data into 1-minute interval data for six representative Dispatchable Plants for calendar
15 year 2010, and the 1-minute data was provided to me. I subsequently verified and re-
16 aggregated the 1-minute data into 10-minute interval data for use in the Schedule 13
17 Intermittent Purchase Obligation studies. Complete datasets of the 1-minute interval and
18 10-minute interval generation for the six representative Dispatchable Plants for calendar
19 year 2010 are contained in Tables 3a-c of my confidential workpapers. I also examined
20 generation data for four of the six representative Dispatchable Plants from calendar year
21 2009, and I noted that the within-the-hour variability of the four Dispatchable Plants
22 during this prior year was very similar to the variability that I observed for calendar year
23 2010.

1 **SECTION III— DETERMINATION OF THE SCHEDULE 13 INTERMITTENT**
2 **PURCHASE OBLIGATION**

4 **Q. Please describe the Schedule 13 Intermittent Purchase Obligation.**

5 A. The Schedule 13 Intermittent Purchase Obligation is a percentage quantity that is used to
6 allocate the cost of the regulation capacity required for PSE to manage the within-the-
7 hour generation variations of wind plants located within the PSE BAA that are exporting
8 energy outside the BAA. In simple terms, it is the percentage of installed wind capacity
9 in PSE's BAA that must be maintained by PSE as flexible within-the-hour generation
10 capacity to manage the variable output from the wind generation on its system. The
11 Intermittent Purchase Obligation is one of the three main billing determinants used to
12 compute an exporting wind plant's charges under Schedule 13.

13 **Q. Please describe the general methodology by which you computed the Intermittent**
14 **Purchase Obligation.**

15 A. I employed a six-step approach to compute the Intermittent Purchase Obligation. These
16 steps mirror, with minor regional differences discussed below, the approach that was
17 approved by the Commission in *Westar*. The first step was to quantify the amount of
18 regulation capacity that is required for PSE to manage within-the-hour variations in its
19 BAA loads, consistent with NERC and WECC reliability criteria. The second step was to
20 quantify the variability of the wind generation located within the PSE BAA on a stand-
21 alone basis by comparing forecast output to actual output on a 10-minute interval basis. I
22 did this for each individual wind plant and for the combination of both wind plants
23 located within the PSE BAA. For purposes of developing the Schedule 13 Intermittent
24 Purchase Obligation, the data for the combination of the two wind plants located within
25 the PSE BAA was used. The third step was to quantify the amount of regulation capacity

1 that is required for PSE to manage within-the-hour variability of all of the Dispatchable
2 Plants located within the PSE BAA. The fourth step was to quantify the total amount of
3 regulation capacity that is required for PSE to manage the combined within-the-hour
4 variations in its BAA loads, wind generation, and Dispatchable Plants and to compute the
5 overall system diversity benefit. In the fifth step, I determined the amount of regulation
6 capacity required to manage within-the-hour wind generation variations by allocating the
7 system diversity benefits determined in Step 4 between PSE's load, wind generation, and
8 Dispatchable Plants. In the sixth and final step, the wind plant regulation capacity value
9 from step 5 was divided by the total Installed Capacity of all wind plants located in the
10 PSE BAA for which PSE is providing regulation capacity services to determine the
11 Schedule 13 Intermittent Purchase Obligation. Each of these steps is described in greater
12 detail *infra*.

13 **Q. How did the approach you employed differ from that taken in *Westar*?**

14 A.: My approach closely followed the methodology approved by the Commission in *Westar*,
15 recognizing that there are regional energy market differences between the Pacific
16 Northwest and the Southwest Power Pool. *Westar* determined the Regulation
17 Requirement of wind plants located within its BAA by quantifying the differences
18 between the wind plant's forecasted output and their actual output based on 10-minute
19 forecasts. That approach was appropriate since *Westar* receives dispatch instructions for
20 many of its generating plants from the Southwest Power Pool on a 10-minute basis.
21 However, PSE and other transmission providers located in the Pacific Northwest region
22 currently operate in an hourly-scheduled, bi-laterally traded market structure. Generation
23 forecasts and associated transmission schedules for wind plants and Dispatchable Plants

1 are currently determined by PSE and other entities in the Pacific Northwest region on an
2 hourly basis. Therefore, PSE must maintain adequate on-system regulating reserves
3 across an hourly timeframe in order to balance the differences between hour-ahead
4 scheduled generation and load versus the actual generation and load that occur across the
5 hour.

6 **Q: Is it reasonable for PSE to use an hourly timeframe to determine PSE's regulation
7 requirement for wind plants located within its BAA?**

8 A: Yes. First, more granular intra-hour scheduling and forecast data is not available to PSE
9 as it was to Westar because of the different regional market structures. In the Pacific
10 Northwest, wind generators do not produce production forecasts every 10 minutes
11 because their schedules can only be adjusted on the hour. If the data were available, and
12 PSE were to utilize the 10-minute measurement period utilized by Westar in order to
13 determine the regulation requirement of wind resources: (1) the computation would
14 vastly underestimate the amount of hourly regulating capacity that PSE actually has to
15 maintain in order to manage wind generation deviations that are occurring on its system,
16 and (2) the computation would be wholly inconsistent with the hourly scheduling
17 structure of the Pacific Northwest power and transmission markets.

18 **Q. What time interval did you utilize when analyzing the amount of within-the-hour
19 variability associated with wind generation, loads, and dispatchable generation in
20 the PSE BAA?**

21 A. My testimony presents an evaluation of the within-the-hour variability of wind
22 generation, loads, and dispatchable generation in the PSE BAA based upon 10-minute
23 interval data.

1 **Q. Does your methodology for the computation of the Schedule 13 Intermittent
2 Purchase Obligation recognize potential diversity impacts between within-the-hour
3 variations in PSE's BAA load, wind generation, and dispatchable generation located
4 in its BAA?**

5 A. Yes. As I will describe in detail later in my testimony, the Intermittent Purchase
6 Obligation incorporates, and gives wind generators full credit for, the benefits of the
7 diversity between within-the-hour variations associated with PSE's BAA load, wind
8 generation, and dispatchable generation.

9 **Q. What study period did you utilize for the computation of the Intermittent Purchase
10 Obligation?**

11 A. The Intermittent Purchase Obligation computations as described in my testimony and as
12 detailed in Table 12 of my confidential workpapers are based upon calendar year 2010
13 historical data. I also confirmed the results of the 2010-based Intermittent Purchase
14 Obligation computations by performing similar calculations using calendar year 2009
15 data; the results of the two studies were very similar with the 2010-based study resulting
16 in a slightly lower Intermittent Purchase Obligation.

17 **Q. What historical data did you utilize for the computation of the Intermittent
18 Purchase Obligation?**

19 A. The specific datasets utilized for the Intermittent Purchase Obligation analysis were: (1)
20 PSE hour-ahead forecasted 2010 BAA loads, (2) hour-ahead forecasted 2010 Wild Horse
21 and Vantage generation, (3) hour-ahead forecasted 2010 generation for selected
22 Dispatchable Plants, (4) PSE actual 10-minute interval 2010 BAA loads, (5) actual 10-
23 minute interval 2010 Wild Horse and Vantage generation, (6) actual 10-minute interval

1 2010 generation for selected Dispatchable Plants, and (7) total 2010 monthly energy
2 production for all Dispatchable Plants located within the PSE BAA. The 10-minute
3 interval datasets were created from base 1-minute interval data. The hour-ahead forecasts
4 of PSE's BAA load were computed by summing together the original day-ahead forecasts
5 and the next-hour load forecast adjustments.

6 **Q. Were 10-minute interval PSE BAA load, wind generation, or Dispatchable Plant
7 forecasts available for calendar year 2010?**

8 A. No. In the WECC, outside of the California Independent System Operator BAA, power
9 transfers between BAA operators are scheduled on an hourly basis. Therefore, PSE and
10 most other entities that operate in the WECC utilize hourly forecasts of load and
11 generation.

12 **Q. How did you convert the available hourly forecast data into 10-minute interval
13 forecasts for calendar year 2010?**

14 A. The forecast quantity for each of the six 10-minute intervals in each hour was set equal to
15 the hourly forecast value. I refer to these quantities as hourly levelized forecasts.

16 **Q. Were the hourly levelized load and generation forecasts adjusted to reflect the
17 generation ramping that occurs at the beginning and end of each scheduling hour in
18 the WECC?**

19 A. Yes. In order to avoid the problems that would occur if generating plants had to
20 instantaneously change their dispatch points at the beginning of each scheduling hour,
21 generating plants in the WECC ramp their output in a linear fashion during the last ten
22 minutes of the current hour and the first 10 minutes of the next hour. When comparing a
23 generating unit's actual output against the forecasted (i.e. prescheduled) value, it is

1 appropriate to include the ramping impact since this represents the “best available”
2 within-the-hour generation forecast. Since the generating plants are ramping to match the
3 hour-to-hour changes in load, it is also appropriate to create ramped load forecasts to
4 represent best available load forecasts.

5 **Q. What was the end result of incorporating load and generation ramping effects into**
6 **the base PSE hourly 2010 BAA load, wind generation, and dispatchable generation**
7 **datasets?**

8 A. By incorporating the top-of-the-hour ramping impacts, a set of best available 10-minute
9 interval PSE BAA load forecasts and a set of best available 10-minute interval PSE wind
10 and dispatchable plant generation forecasts were created from the hourly leveled
11 forecasts. These 10-minute interval load and 10-minute interval wind/dispatchable plant
12 generation forecasts were then compared against the actual 10-minute load and
13 wind/dispatchable plant generation values to compute: (1) 10-minute interval load
14 deviations, (2) 10-minute interval wind generation deviations, and (3) 10-minute interval
15 Dispatchable Plant generation deviations. Complete datasets of the hourly leveled
16 forecasts and the hourly ramped forecasts for PSE’s BAA load, the Wild Horse and
17 Vantage wind plants, and the six representative Dispatchable Plants are contained in
18 Tables 4, 5, and 6 of my confidential workpapers.

19 **Q. Please describe how the 10-minute PSE load deviation quantities were used in the**
20 **first step of the Intermittent Purchase Obligation computation.**

21 A. The 10-minute interval PSE load forecast versus actual load deviations were computed
22 using the calendar year 2010 data. This computation resulted in a total of 52,560 10-
23 minute load forecast versus actual load deviation quantities. Then, the standard deviation

1 of this dataset was computed. Finally, multiplying the standard deviation by two, I
2 established the 95% confidence interval: this resulted in a figure of 71.00 MW. In simple
3 terms this means PSE, over the course of the year and on a stand-alone basis, needs 71.00
4 MW of flexible and quick reacting capacity available to be 95% confident of meeting its
5 BAA obligation to manage within-hour load variations. Details regarding the
6 computation of the stand-alone BAA load regulation requirement are contained in Table
7 7 of my confidential workpapers.

8 **Q. Why did you choose to use a 95% confidence interval?**

9 A. The 95% confidence interval was chosen as a reasonable balance between: (1) using a
10 highly conservative measure so that PSE would be assured of meeting virtually all
11 within-the-hour BAA load variations, i.e. a probability approaching 100%, and (2)
12 ensuring that PSE can continue to meet the NERC CPS2 reliability criteria which is based
13 upon a 90% performance metric. Using a 95% confidence interval for determining the
14 expected value of the Regulation Capacity required to manage within-the-hour variations
15 in PSE's BAA load is reasonable given that using a lower confidence interval would
16 likely: (1) degrade PSE's CPS2 performance, and/or (2) would result in PSE absorbing
17 additional costs not recovered through Schedule 13 in order for it to continue to meet the
18 CPS2 criteria. However, as PSE gains more experience in managing increasing amounts
19 of wind generation variability in its BAA under various system operating conditions, use
20 of a confidence interval greater than 95% may be necessary in order for PSE to continue
21 to meet NERC reliability criteria.

22 **Q. Is the use of a 95% confidence interval consistent with *Westar*?**

1 A. Yes. Westar's Schedule 3A regulation tariff that was recently approved by the
2 Commission also incorporated a 95% confidence interval for the determination of the
3 applicable regulation allocation factors. I note, however, that at least one other provider
4 of within-the-hour wind regulation services utilizes a confidence interval greater than
5 95%: BPA's current Wind Integration Tariff (pursuant to which PSE itself purchases
6 wind balancing services for its Hopkins Ridge and Klondike III wind plants) incorporates
7 a 99.5% confidence interval. I note that PSE's Schedule 13 Intermittent Purchase
8 Obligation would be 50% higher than the proposed figure if PSE chose to utilize the
9 same 99.5% confidence interval as is currently being utilized by BPA.

10 **Q. Please describe the second step of the Intermittent Purchase Obligation
11 computation.**

12 A. In the second step of the Intermittent Purchase Obligation computation, the 10-minute
13 Wild Horse forecast versus actual generation deviations and the 10-minute Vantage plant
14 forecast versus actual generation deviations were computed using calendar year 2010
15 data. For the Vantage plant, only data for the time period that the plant was in
16 commercial operation (October 4, 2010 – December 31, 2010) was used in the
17 determination of the Intermittent Purchase Obligation. The next-hour forecasts for both
18 the Wild Horse and Vantage wind plants were persistence-based forecasts that were
19 developed by using the actual average generation value for the first minute of hour t as
20 the leveled generation forecast for hour t + 1 (i.e. a 60-minute before the hour
21 persistence forecast). This computation resulted in a total of 52,560 10-minute interval
22 forecast versus actual generation deviation quantities for Wild Horse plant and 12,816
23 10-minute deviations for the Vantage plant. Next, the 10-minute forecast versus actual

1 deviations for the two wind plants were combined, and the standard deviation of the
2 combined dataset was computed. Finally, using two times the standard deviation I
3 established the 95% confidence interval: this resulted in a figure of 77.80 MW. Details
4 regarding the computation of the stand-alone wind plant regulation requirement are
5 contained in Table 8 of my confidential workpapers.

6 **Q. What does the 77.80 MW figure you refer to above represent?**

7 A. The 77.80 MW figure represents the expected stand-alone amount of within-the-hour
8 variation of the combined generation output of the Wild Horse and Vantage wind plants
9 within a 95% confidence interval. This figure represents the amount of within-the-hour
10 Regulation Capacity that PSE would need to maintain in order to manage wind
11 generation variability operating *in isolation* from the rest of its system. This figure does
12 not incorporate PSE load variations or Dispatchable Plant variations; therefore potential
13 system diversity is not reflected in this figure. Without incorporating these system
14 diversity benefits, the stand-alone Intermittent Purchase Obligation would be 26.25%.

15 **Q. Please describe the third step of the Intermittent Purchase Obligation computation.**

16 A. In the third step of the Intermittent Purchase Obligation computation, the 10-minute
17 Dispatchable Plant forecast versus actual generation deviations were computed for all of
18 the calendar year 2010 data. The purpose of this calculation is to determine the amount
19 of system variability attributable to PSE's dispatchable generation resources in order to
20 perform the portfolio-wide analysis described in step five, *infra*. Unlike Westar's
21 situation, PSE does not receive dispatch instructions from a power pool or other third
22 party. Therefore, PSE cannot determine the regulation requirement of its dispatchable
23 generating plants in the exact same fashion as Westar did in their recent Schedule 3A

1 filing since the dispatch instruction data – which in Westar’s case represented the forecast
2 for each dispatchable plant under the SPP’s control for the upcoming 10-minute interval
3 – is simply not available in PSE’s case. I therefore employed a different methodology to
4 create hour-ahead forecasts for PSE’s Dispatchable Plants that was based upon the
5 available data. As detailed below, this methodology reasonably replicates Westar’s
6 approach using the best data currently available to PSE.

7 **Q: Please describe the methodology that you utilized to determine the hourly scheduled
8 versus actual deviations for PSE’s Dispatchable Plants.**

9 A: First, I chose six plants from PSE’s fleet of dispatchable generating resources to represent
10 each of the three main categories of resource types that PSE operates: (1) the Colstrip
11 1&2 and Colstrip 3&4 plants were chosen to represent coal-fired steam plants, (2) the
12 Goldendale and Sumas plants were chosen to represent natural gas-fueled
13 CCCT/CT/misc thermal plants, and (3) the Upper Baker and Lower Baker plants were
14 chosen to represent hydroelectric plants. Next, the operation of each of the six
15 representative plants was analyzed across calendar year 2010 to determine the periods
16 when the plant was operated in a steady-state mode. All hours in which the plant was: (1)
17 not being intentionally ramped up or down, or (2) was not being limited by a partial or
18 full unit forced outage were considered to be steady-state periods. Next, a set of 60-
19 minute before-the-hour persistence forecasts were created for each representative plant.
20 A cross-check was then performed to ensure that each 60-minute persistence forecast was
21 determined at a point in time when the plant was operating in a steady-state mode. The
22 hourly leveled forecasts created from the previous step were then ramped across the last
23 10 minutes of each hour and the first 10 minutes of the next hour in order to be consistent

1 with the top of the hour ramping procedure used in the WECC. Finally, the difference
2 between the hour-ahead ramped forecasts and the actual generation for each
3 representative plant were computed across each 10-minute period for all of the steady-
4 state hours for that particular plant during calendar year 2010. Complete datasets of the
5 hourly leveled forecasts and the hourly ramped forecasts for the six representative
6 Dispatchable Plants are contained in Table 6 of my confidential workpapers. Details
7 regarding the identification of the steady-state operating periods for each representative
8 Dispatchable Plant are contained in Tables 9a-c of my confidential workpapers.

9 **Q: Is it reasonable to utilize a 60-minute in advance of the hour persistence forecast in
10 order to determine the within-the-hour variability of PSE's representative
11 Dispatchable Plants?**

12 A: Yes. As I previously mentioned, PSE does not receive dispatch instruction from a power
13 pool or other third party that could be used to determine each generator's next-hour
14 schedule. Also, while PSE creates and maintains day-ahead schedules for all of its
15 dispatchable generating plants, PSE does not create and maintain a complete set of
16 revised, hour-ahead schedules in real-time. Using 60 minute before the hour persistence
17 forecasts for PSE's dispatchable plants is therefore a reasonable approach to determine
18 the expected next-hour generation level from each plant during steady-state operating
19 periods.

20 **Q: Is the use of 60-minute before-the-hour persistence forecasts to determine the
21 regulation requirement of PSE's dispatchable generating plants consistent with how
22 you determined the scheduled versus actual deviations of the wind plants located
23 within the PSE BAA?**

1 A: Yes. I determined the within-the-hour regulation requirement of the wind plants located
2 within the PSE BAA by comparing 60-minute in advance of the hour persistence
3 forecasts against the actual wind generation that occurred within each 10-minute period
4 during that same hour. The methodologies for determining the within-the-hour regulation
5 requirement of PSE's Dispatchable Plants and the wind plants located within PSE's BAA
6 are therefore consistent.

7 **Q: Is it reasonable to exclude the hours on which there was an intentional ramping
8 operation on a plant from the computation of the scheduled versus actual generation
9 deviations for the six representative PSE Dispatchable Plants?**

10 A: Yes. The intent of the computation described above is to quantify the random fluctuations
11 between a representative Dispatchable Plant's expected operation – as measured via a 60-
12 minute before the hour persistence forecast – and its actual operation. Deviations
13 resulting from a dispatchable plant being *intentionally* ramped up or down within an hour
14 while under PSE's operational control are obviously not random in nature and such
15 "deviations" should not be considered when determining the within-the-hour regulation
16 requirement of the representative Dispatchable Plants.

17 **Q: Is it reasonable to exclude the hours on which there were partial or full forced
18 outages on a plant from the computation of the scheduled versus actual generation
19 deviations for the six representative PSE Dispatchable Plants?**

20 A: Yes. The intent of the forecast versus actual deviation computation is to quantify the
21 within-the-hour regulation requirement of PSE's Dispatchable Plants. In addition to
22 maintaining regulation capacity reserves, PSE also maintains a separate pool of
23 contingency capacity reserves that are available to respond to partial or full forced

1 outages on its thermal and/or hydroelectric plants. Therefore, if one of the representative
2 Dispatchable Plants suffers a partial or full forced outage, such an event could be covered
3 by PSE's contingency capacity reserves and not PSE's regulation reserves.

4 **Q: How were the forecast versus actual generation deviations of the six representative**
5 **PSE Dispatchable Plants used to determine the overall variability of all of PSE's**
6 **Dispatchable Plants?**

7 A: The 10-minute interval scheduled versus actual deviations as measured across all of the
8 steady-state hours during each month of calendar year 2010 were scaled up by the ratio of
9 the total amount of monthly energy production from all Dispatchable Plants within that
10 class (coal-fired steam, CCCT/CT/Misc, or hydro) that were electrically located within
11 the PSE BAA, divided by the total monthly energy production of the two representative
12 Dispatchable Plants. The scaled up 10-minute deviations for all three of the PSE plant
13 classes were then combined with the 10-minute PSE load deviations and the 10-minute
14 wind deviations in order to determine PSE's overall within-the-hour regulation
15 requirement. Details regarding the computation of the coal-fired steam plant,
16 CCCT/CT/Misc plant, and hydro plant scaling factors are contained in Table 10 of my
17 confidential workpapers.

18 **Q. What were the results from Step 3 of the Intermittent Purchase Obligation**
19 **computation regarding the schedule versus actual deviations for PSE's Dispatchable**
20 **Plants?**

21 A. Prior to the applying the scaling-up process, the 95% confidence figures for the six
22 representative Dispatchable Plants were as follows: (1) Colstrip 1&2 – 6.07 MW, (2)
23 Colstrip 3&4 – 5.04 MW, (3) Goldendale – 2.53 MW, (4) Sumas – 1.11 MW, (5) Upper

1 Baker – 0.42 MW, and (6) Lower Baker – 1.14 MW. After applying the scaling factors,
2 the results for the three classes of PSE plants were: (1) Coal-Fired Steam plants – 8.53
3 MW, (2) Gas/Oil-Fired CCCT/CT/Misc plants – 7.53 MW, and (3) Hydroelectric plants
4 1.99 MW. Details regarding the computation of the stand-alone regulation requirements
5 for each of the six representative plants are contained in Tables 9a-c of my confidential
6 workpapers. Details regarding the application of the scaling factors in order to determine
7 the stand-alone regulation requirement of each of the three plant classes are contained in
8 Table 11 of my confidential workpapers.

9 **Q. What do the 8.53 MW, 7.53 MW, and 1.99 MW figures you refer to above
10 represent?**

11 A. These three MW figures represent the stand-alone amounts of the within-the-hour
12 Regulation Capacity that PSE must maintain within its BAA in order to manage the
13 within-the-hour forecasted versus actual generation deviations of each of its three classes
14 of Dispatchable Plants with a 95% confidence.

15 **Q. What is the fourth step in the determination of the Intermittent Purchase
16 Obligation?**

17 A. In the fourth step of the Intermittent Purchase Obligation computation, I determined the
18 calendar year 2010 total within-the-hour regulation requirement of the combination of the
19 PSE load deviations, the wind plant generation deviations, and the Dispatchable Plant
20 generation deviations using a 95% confidence interval.

21 **Q. Are the 95% confidence regulation figures that you previously computed in Steps 1-
22 3 of the Intermittent Purchase Obligation computation for PSE's load, wind
23 generation, and dispatchable generation directly additive?**

1 A. No. Adding the regulation requirements that were determined in Steps 1-3, which were
2 computed on a stand-alone basis, would fail to take into account system diversity
3 impacts. In other words, because the 10-minute load, wind generation, and dispatchable
4 plant generation deviations are sometimes offsetting, simply adding the individual 95%
5 confidence figures would overstate the combined impacts of all the sources of deviation.
6 For instance, if a particular 10-minute wind generation deviation was a positive 20 MW
7 and the Dispatchable Plant generation deviation during the same interval was negative 5
8 MW, the net regulation requirement for all generating plants during that interval would
9 be only positive 15 MW.

10 **Q. How did you determine the overall within-the-hour regulation requirement of the
11 PSE system?**

12 A. Using the same set of 10-minute deviations that were determined in Steps 1-3, I first
13 determined the variance of each of the five elements that are included in the Regulation
14 study. The five elements included in the study are: (1) PSE load deviations, (2) PSE
15 wind generation deviations, (3) PSE coal-fired thermal plant generation deviations, (4)
16 PSE CCCT/CT/Misc plant generation deviations, and (5) PSE hydroelectric plant
17 generation deviations. Next, I determined the covariance between each pair of the five
18 elements during the steady-state periods common to each element pair. Then I added the
19 variance for each individual element together with the covariances between that element
20 and the other four elements to determine the Adjusted Variance for each element. The
21 95% confidence regulation requirement for the combination of all five elements was then
22 determined by summing the five Adjusted Variance figures, taking the square root, and
23 multiplying by two. The result of this computation was 106.27 MW, which represents the

1 overall calendar year 2010 within-the-hour regulation requirement of the PSE system.

2 The following table illustrates this set of computations:

	Individual Std Dev (MW)	Covariance with PSE Load (MW)	Covariance with Wind Plants (MW)	Covariance with Coal Plants (MW)	Covariance with Hydro Plants (MW)	Covariance with CCCT/ CT/Misc (MW)	Adjusted Variance
PSE BAA Load	35.50		8.36	1.29	(0.99)	(2.57)	1,266.4
Wind Plants	38.90	8.36		(0.27)	0.25	1.27	1,522.8
Coal-Fired Steam Plants	4.27	1.29	(0.27)		0.09	0.58	19.9
Hydro Plants	0.99	(0.99)	0.25	0.09		0.08	0.4
CCCT/CT/Misc Plants	3.77	(2.57)	1.27	0.58	0.08		13.5
					Total Adjusted Variance	2,823.1	
					Total 2*Standard Deviation	106.27	

3

4 **Q. Does the 106.27 MW figure incorporate the diversity between variations in PSE's
5 BAA load, wind generation, and dispatchable generation located within the PSE
6 BAA?**

7 A. Yes. Diversity impacts between load, wind generation, and dispatchable generation
8 deviations within the PSE BAA reduced the overall 95% confidence within-the-hour
9 regulation requirement by approximately 36%, as compared to the sum of the stand-alone
10 regulation requirements.

11 **Q. What is the fifth step in determining the Intermittent Purchase Obligation?**

12 A. The fifth step in the Intermittent Purchase Obligation computation is to allocate a portion
13 of the overall system diversity benefit to the wind plants located within the PSE BAA,
14 thereby reducing the within-the-hour wind plant regulation requirement. The initial step
15 in this process is to determine the PSE system diversity benefit ratio. This ratio is
16 computed by calculating the 95% confidence value for the combination of the five
17 elements (which is the square root of the sum of the five Adjusted Variances, multiplied
18 by two) and then dividing by the sum of the 95% confidence value for each of the
19 individual five elements in the regulation study (which is the square root of each

1 element's Adjusted Variance multiplied by two. The result of this computation is 0.637,
 2 which is the PSE system diversity ratio. To determine the within-the-hour regulation
 3 requirement of the wind plants located within the PSE BAA, the 95% confidence value
 4 for the wind plants (which is the square root of the wind plants' Adjusted Variance
 5 multiplied by two) is multiplied by the system diversity ratio, which results in a final
 6 within-the-hour wind regulation requirement of 49.72 MW. The following table shows
 7 the Step 5 results.

8

	Regulation Allocation (MW)	Regulation Allocation (%)
PSE BAA Load	45.34	
Wind Plants	49.72	16.77
Coal-Fired Steam Plants	5.68	
Hydro Plants	0.83	
CCCT/CT/Misc Plants	4.69	
Total Regulation Requirement	106.27	

9

10 **Q. What is the sixth and final step in the Intermittent Purchase Obligation**
 11 **determination?**

12 A. The wind plant within-the-hour regulation requirement determined in Step 5 is divided by
 13 the total installed capacity of all of the wind plants located within the PSE BAA for
 14 which PSE is providing regulation service in order to determine the Intermittent Purchase
 15 Obligation. This computation results in an Intermittent Purchase Obligation of 16.77%
 16 (49.72 MW wind regulation requirement divided by 296.41 MW of installed wind plant
 17 capacity). The 296.41 MW installed capacity figure was pro-rated across calendar year
 18 2010 to reflect the fact that the 96 MW Vantage Plant was in commercial operation only
 19 during the period October 4, 2010 – December 31, 2010. Therefore, given calendar year

1 2010 historical data, PSE would need to maintain wind plant regulation reserves in the
2 amount of 16.77% of the total installed wind capacity located within the PSE BAA in
3 order to manage the within-the-hour wind generation deviations with a 95% confidence.
4 The complete 10-minute interval detail of the Intermittent Purchase Obligation
5 computation is contained in Table 12 of my confidential workpapers.

6 **Q. Did the portfolio wide approach significantly reduce the Schedule 13 purchase**
7 **obligation of wind and other intermittent generation resources?**

8 A. Yes. Giving wind generators the full benefit of offsetting system diversity resulted in a
9 36% reduction in the Intermittent Purchase Obligation.

10 Q: Is the methodology that you employed to determine overall system diversity benefits
11 in the computation of the Schedule 13 Intermittent Purchase Obligation consistent
12 with the methodologies employed in *Westar*?

13 A: Yes. The methodology by which I determined system diversity impacts between the five
14 elements in the PSE regulation study and the method by which I allocated a portion of the
15 system diversity benefit to wind plants located within the PSE BAA is consistent with the
16 approach that the Commission previously approved in *Westar*. I note that while the
17 Westar regulation studies used a slightly different categorization of the sources of
18 deviations than the PSE studies, the two sets of studies are consistent in how system
19 diversity impacts were determined and how those benefits were allocated between the
20 different sources of deviation.

21 Q: Do you believe that the 16.77% regulation percentage as determined above for wind
22 and other non-dispatchable plants located within the PSE BAA is a conservative

1 **measure of the amount of flexible capacity that PSE must reserve in order to**
2 **manage within-the-hour intermittent plant deviations?**

3 A: Yes. I believe that the 16.77% Intermittent Purchase Obligation, which was developed
4 pursuant to the general methodology that the Commission approved in *Westar*, likely
5 understates the full range of incremental and decremental capacity that PSE must
6 maintain in order to manage within-the-hour wind generation deviations with a 95%
7 confidence.

8 **Q: Please explain.**

9 A: In my experience in developing day-ahead load forecasts for the PSE system across a 9
10 year period, I have observed that both the direction and relative magnitude of load ramps
11 on the PSE system are generally predictable to a high degree of accuracy. For instance,
12 on weekdays, the PSE system would experience a rapid upward load ramp during
13 scheduling hours 0600 and 0700 that would require that PSE maintain incremental
14 capacity reserves – but virtually no decremental capacity reserves – in order to manage
15 the load pickup across these hours. Likewise, on scheduling hours 2200 and 2300 PSE's
16 loads tend to decrease rapidly, which requires PSE to maintain decremental capacity
17 reserves - but virtually no incremental capacity reserves – across these hours.

18 **Q: Do changes in wind plant generation within the PSE BAA follow the same basic**
19 **ramping patterns as what is observed for PSE's loads?**

20 A: No. Wind plant ramping events on the PSE system are much more difficult to predict
21 than PSE's load ramping events. Also, the *direction* of wind generation ramping events is
22 more uncertain than the direction of load ramping events. In addition, PSE has
23 experienced wind ramping events in both directions during the same hour. This inherent

1 characteristic of wind generation means that PSE must maintain both incremental *and*
2 decremental capacity reserves during many hours in order to manage wind plant
3 generation that could ramp unexpectedly in *either* direction.

4 **Q: Does the methodology accepted by the Commission in *Westar* fully account for both**
5 **the incremental and decremental capacity requirements that PSE must maintain in**
6 **order to manage generation deviations from wind plants located within its BAA**
7 **with a 95% confidence?**

8 A: In my opinion, the methodology accepted by the Commission in *Westar*, while
9 reasonable in many respects, does not fully account for the fact that wind generation
10 ramping events are more unpredictable than load ramping events. By multiplying the
11 standard deviation of the forecast versus actual wind deviations by 2 (instead of 4), the
12 *Westar* methodology understates the total range of flexible capacity – both incremental
13 and decremental capacity – that a BAA operator is required to maintain under actual
14 operating conditions in order to manage wind ramping events (which could occur in
15 either direction) with a 95% confidence. The Commission’s recent Notice of Proposed
16 Rulemaking on Frequency Regulation in Organized Markets recognizes this principle.²

17 **Q. What is the significance of this observation?**

18 A. I make this observation only to highlight that, by following the “divide-by-two” approach
19 approved by the Commission in *Westar*, PSE has elected to take a conservative approach
20 to cost recovery under Schedule 13.

21

22 **SECTION IV– DETERMINATION OF THE SCHEDULE 13 CHARGE FOR**
23 **REGULATION AND FREQUENCY RESPONSE SERVICE**

²*Frequency Regulation Compensation in Organized Wholesale Power Markets*, Notice of Proposed Rulemaking, 76 Fed. Reg. 11,177 (Mar. 1, 2011), 134 FERC ¶ 61,124 (2011).

1

2 **Q. How are a transmission customer's charges under PSE's Schedule 13 determined?**

3 A. As demonstrated in Statement BL, which I support and sponsor, and which is attached to
4 my testimony as Exhibit PSE-101, a transmission customer's charges under PSE's
5 Schedule 13 are determined via three billing determinants: (1) the customer's reserved
6 transmission amount, (2) the purchase obligation, and (3) the capacity rate.

7 **Q. Please describe the capacity rate component of PSE's Schedule 13.**

8 A. The capacity rate represents PSE's capacity-related costs of providing within-the-hour
9 regulation and frequency response service under both OATT Schedules 3 and 13. This
10 rate, as determined in the testimony of Mr. Story, is \$12.39 per Kilowatt-month. This
11 figure was derived from the capacity-related costs of the pool of existing PSE generating
12 units that are capable of supplying within-the-hour regulation and frequency response
13 capacity as described in the testimony of Mr. Tongue.

14 **Q. How was the Schedule 13 capacity rate of \$12.39 / kW-month determined?**

15 A. The \$12.39 / kW-month capacity rate was determined via a plant capacity-weighted cost
16 computation; the details of this computation are contained in Exhibit PSE-501, Period II
17 Statement BK – By Plant. I note that the capacity figures used in Statement BK – By
18 Plant are representative of the actual amount of regulating capacity that each resource is
19 capable of providing.³

20 **Q. Please describe the purchase obligation component of PSE's Schedule 13.**

³ The plant capacity figures cited in Statement BK – By Plant (Exhibit PSE-501) were taken directly from PSE's 2010 FERC Form 1 Report. Capacity figures for the PSE thermal plants are the "Net Continuous Plant Capability When Not Limited by Condenser Water" ratings. Capacity figures for the PSE hydro plants are the "Net Plant Capability Under Most Favorable Oper[ating] Conditions" ratings.

1 A. The purchase obligation is a percentage quantity that is determined based upon the type
2 of generating resource for which PSE is providing regulation and frequency response
3 service. For wind plants (and other intermittent, non-dispatchable generating resources
4 such as solar) the purchase obligation is 16.77%; the derivation of this percentage was
5 previously described in Section III of my testimony. For all non-wind and non-
6 intermittent generating resources, which I collectively refer to as Dispatchable Resources,
7 the purchase obligation is 2.00%.

8 **Q. How is the monthly charge for regulation and frequency response service supplied
9 by PSE to exporting wind resources under Schedule 13 determined?**

10 A. An exporting wind plant's monthly charge for regulation and frequency response service
11 under Schedule 13 is computed by multiplying the transmission customer's reserved
12 transmission capacity times a purchase obligation of 16.77% times the capacity rate. For
13 example, a customer that has reserved 100,000 kW of transmission and who is exporting
14 capacity and energy from a wind resource out of the PSE BAA would be assessed a
15 monthly charge under Schedule 13 as follows:

$$100,000 \text{ kW} * 16.77\% * \$12.39 / \text{kW-month} = \$207,780 \text{ per month}$$

16 **Q. How is the monthly charge for regulation and frequency response service supplied
17 by PSE to exporting Dispatchable Resources under Schedule 13 determined?**

18 A. An exporting Dispatchable Resource's monthly charge for regulation and frequency
19 response service under Schedule 13 is computed by multiplying the transmission
20 customer's reserved transmission capacity times a purchase obligation of 2.00% times the
21 capacity rate. For example, a customer that has reserved 100,000 kW of transmission and

1 who is exporting capacity and energy from a dispatchable resource out of the PSE BAA
2 would be assessed a monthly charge under Schedule 13 as follows:

3 $100,000 \text{ kW} * 2.00\% * \$12.39 / \text{kW-month} = \$24,780 \text{ per month}$

4 **Q. How do the charges assessed to exporting wind plants for regulation and frequency**
5 **response service under PSE's Schedule 13 compare with the charges assessed by**
6 **BPA pursuant to its within-the-hour Wind Balancing Service?**

7 A. BPA's Wind Balancing Service, as recently implemented by BPA as part of its 2010
8 transmission rate case, is similar to PSE's Schedule 13 in that both tariffs strive to
9 recover the additional costs beyond the energy costs recovered in Schedule 9 for
10 Generator Imbalance service associated with managing within-the-hour wind generation
11 variations. However, the two rates are not directly comparable due to significant
12 differences in the quality of the regulation service being provided. BPA's originally
13 proposed Wind Balancing Service rate, for a within-the-hour wind regulation product of
14 similar quality to that being provided by PSE under Schedule 13, was \$2.72 / kW-month.
15 After holding a series of discussions with its customers, BPA agreed to reduce its final
16 Wind Balancing Services rate to between \$1.29/kW-month and \$1.58/kW-month. The
17 comparable rate assessed to exporting wind plants under PSE's updated Schedule 13
18 would be approximately \$2.08 / kW-month (equal to the capacity cost of \$12.39/kW-
19 month times the 16.77% purchase obligation). However, in exchange for agreeing to a
20 lower Wind Balancing Rate, BPA gained the ability to significantly limit in real-time the
21 amount of within-the-hour regulating capacity that it makes available to existing and new
22 wind plants located within its BAA. Once BPA reaches this regulating capacity cap, wind
23 plants in the BPA BAA must follow BPA dispatch instructions to curtail their generation

1 output. In addition, as part of its ongoing FY2012 transmission rate case process, BPA
2 has presented proposals that would: 1) restrict the amount of regulation capacity that
3 BPA makes available on a long-term basis to existing and new wind plants located within
4 its BAA, and 2) have BPA charge higher rates for wind balancing services that have
5 lower probabilities of curtailments and/or limitations.

6 **Q. Is PSE proposing under Schedule 13 to limit the amount of regulation and**
7 **frequency response capacity that it makes available to existing and/or new wind**
8 **plants located within its BAA?**

9 A. No. Unlike BPA, PSE is not proposing to limit the amount of regulation and frequency
10 response capacity that it provides to either existing or new wind plants located within its
11 BAA, except to the extent required to maintain system reliability pursuant to WECC and
12 NERC reliability criteria.

13 **Q. Does this conclude your testimony?**

14 A. Yes.

UNITED STATES OF AMERICA
BEFORE THE
FEDERAL ENERGY REGULATORY COMMISSION

Puget Sound Energy, Inc.

)

Docket No. ER11-__-000


AFFIDAVIT OF LLOYD C. REED

Lloyd C. Reed, being first duly sworn, deposes and states that he is the Lloyd C. Reed referred to in the document entitled "Prepared Direct Testimony of Lloyd C. Reed on Behalf of Puget Sound Energy, Inc.," that any exhibits accompanying that document were prepared by him or under his direction, that he has read such testimony and is familiar with the contents thereof, and that the facts set forth therein are true and correct to the best of his knowledge, information and belief in this proceeding.




Lloyd C. Reed

SUBSCRIBED AND SWORN TO before me, the undersigned notary public, this
____ day of May, 2011.



Shawnna Watson
Notary Public

My Commission Expires: My Commission Expires
March 31, 2014



Statement BL - Period I
Puget Sound Energy
Rate Design Information

Charges for Regulation and Frequency Response Service Under Schedule 3

A transmission customer's charges for purchasing Regulation and Frequency Response Service under Schedule 3 are computed based upon the following billing determinates: 1) the customer's reserved capacity for Point to Point Transmission Service or Network Integration Transmission Service, 2) the purchase obligation, and 3) the capacity cost.

The purchase obligation is 2.00%. This percentage remains unchanged from the currently-in-effect Schedule 3.

The capacity cost, as derived in Statement BK by Plant, is \$11.67/KW-month. This cost has been updated to reflect PSE's current cost of providing Regulation and Frequency Response Service.

The monthly charge for a transmission customer with a 100,000 KW transmission reservation that is purchasing Regulation and Frequency Response Service under Schedule 3 is determined as follows:

$$\text{Monthly Schedule 3 Charge} = 100,000 \text{ KW} * 2.00\% * \$11.67/\text{KW-month} = \$23,340$$

Statement BL - Period I
Puget Sound Energy
Rate Design Information

2) Charges for Regulation and Frequency Response Service Under Schedule 13

A transmission customer's charges for purchasing Regulation and Frequency Response Service under Schedule 13 are computed based upon the following billing determinates: 1) the customer's reserved capacity for Point to Point Transmission Service or or Network Integration Transmission Service, 2) the purchase obligation, and 3) the capacity cost.

The purchase obligation for dispatchable generating resources that are delivering energy outside of the PSE control area is 2.00%. This percentage remains unchanged from the currently-in-effect Schedule 13.

The purchase obligation for wind plants and/or other intermittent generating resources that are delivering energy outside of the PSE control area is 16.77%. This percentage, as derived in the testimony of Mr. Lloyd Reed, reflects the additional amount regulating capacity that PSE must maintain in order to manage the within-the-hour generation deviations of wind plants and/or other intermittent generating plants.

The capacity cost, as derived in Statement BK by Plant, is \$11.67/KW-month. This cost has been updated to reflect PSE's current cost of providing Regulation and Frequency Response Service.

The monthly charge for a transmission customer with a 100,000 KW transmission reservation that is purchasing Regulation and Frequency Response Service under Schedule 13 in order to export energy from a dispatchable generating resource is determined as follows:

$$\text{Monthly Schedule 13 Charge} = 100,000 \text{ KW} * 2.00\% * \$11.67/\text{KW-month} = \$23,340$$

The monthly charge for a transmission customer with a 100,000 KW transmission reservation that is purchasing Regulation and Frequency Response Service under Schedule 13 in order to export energy from a wind plant and/or other intermittent generating resource is determined as follows:

$$\text{Monthly Schedule 13 Charge} = 100,000 \text{ KW} * 16.77\% * \$11.67/\text{KW-month} = \$195,705$$

Statement BL - Period II
Puget Sound Energy
Rate Design Information

1) Charges for Regulation and Frequency Response Service Under Schedule 3

A transmission customer's charges for purchasing Regulation and Frequency Response Service under Schedule 3 are computed based upon the following billing determinates: 1) the customer's reserved capacity for Point to Point Transmission Service or Network Integration Transmission Service, 2) the purchase obligation, and 3) the capacity cost.

The purchase obligation is 2.00%. This percentage remains unchanged from the currently-in-effect Schedule 3.

The capacity cost, as derived in Statement BK by Plant, is \$12.39/KW-month. This cost has been updated to reflect PSE's current cost of providing Regulation and Frequency Response Service.

The monthly charge for a transmission customer with a 100,000 KW transmission reservation that is purchasing Regulation and Frequency Response Service under Schedule 3 is determined as follows:

$$\text{Monthly Schedule 3 Charge} = 100,000 \text{ KW} * 2.00\% * \$12.39/\text{KW-month} = \$24,780$$

Statement BL - Period II
Puget Sound Energy
Rate Design Information

2) Charges for Regulation and Frequency Response Service Under Schedule 13

A transmission customer's charges for purchasing Regulation and Frequency Response Service under Schedule 13 are computed based upon the following billing determinates: 1) the customer's reserved capacity for Point to Point Transmission Service or or Network Integration Transmission Service, 2) the purchase obligation, and 3) the capacity cost.

The purchase obligation for dispatchable generating resources that are delivering energy outside of the PSE control area is 2.00%. This percentage remains unchanged from the currently-in-effect Schedule 13.

The purchase obligation for wind plants and/or other intermittent generating resources that are delivering energy outside of the PSE control area is 16.77%. This percentage, as derived in the testimony of Mr. Lloyd Reed, reflects the additional amount regulating capacity that PSE must maintain in order to manage the within-the-hour generation deviations of wind plants and/or other intermittent generating plants.

The capacity cost, as derived in Statement BK by Plant, is \$12.39/KW-month. This cost has been updated to reflect PSE's current cost of providing Regulation and Frequency Response Service.

The monthly charge for a transmission customer with a 100,000 KW transmission reservation that is purchasing Regulation and Frequency Response Service under Schedule 13 in order to export energy from a dispatchable generating resource is determined as follows:

$$\text{Monthly Schedule 13 Charge} = 100,000 \text{ KW} * 2.00\% * \$12.39/\text{KW-month} = \$24,780$$

The monthly charge for a transmission customer with a 100,000 KW transmission reservation that is purchasing Regulation and Frequency Response Service under Schedule 13 in order to export energy from a wind plant and/or other intermittent generating resource is determined as follows:

$$\text{Monthly Schedule 13 Charge} = 100,000 \text{ KW} * 16.77\% * \$12.39/\text{KW-month} = \$207,780$$