

Updated March 5, 2009

Puget Sound Energy (PSEI) posts an OASIS path referred to as PSEI.SYSTEM-ORCAS.

The TTC currently posted for this path is based on the Winter/Spring-Fall/Summer ratings for #4/0 ACSR conductor operating at 100 degrees C. The TTC is as follows:

104 MWs for November 16 through March 16

95 MWs for March 16 through July 1

88 MWs for July 1 through November 16