System Unique Loading Report

Case Name: *18hs1pPTI_CLRTPGr0*
as compared to: *18hs1p*

From Bus	To Bus	Circuit	Most Severe Contingency	Rating(MVA)	Max Percent	Count
AM EAST 115.00	BAYFIELD 115.00	1	FLOR.RIV 115.00-HESPERUS 115.00 CIRCUIT 1	128	135	1
AM EAST 115.00	FLOR.RIV 115.00	1	FLOR.RIV 115.00-HESPERUS 115.00 CIRCUIT 1	128	107.6	2
AREQUGCH 115.00	W CANON 115.00	1	CANONCTY 69.000-CANONCTY 115.00 CIRCUIT 1	87	106.9	1
B.CK PS 115.00	B.CK PS 230.00	T1	B.CK PS 115.00-BEAVERCK 115.00 CIRCUIT 1	224	104.1	1
BANCROFT 115.00	SOUTH1TP 115.00	1	BANCROFT 115.00-GRAY ST 115.00 CIRCUIT 1	135	96.9	1
BAYFIELD 115.00	DURANGO 115.00	1	FLOR.RIV 115.00-HESPERUS 115.00 CIRCUIT 1	232.5	118.2	1
BIRDSALE 115.00	TEMPLTON 115.00	1	DRAKE N 115.00-FAIRVWCS 115.00 CIRCUIT 1	86	96.2	1
BO TERM 115.00	SUNSHTAP 115.00	1	ELDORADO 115.00-VALMONT 115.00 CIRCUIT 1	108	108.7	1
BOONE 115.00	BOONE 230.00	1	LAMAR CO 115.00-WILOW CK 115.00 CIRCUIT 1	150	99.5	1
BOONE 115.00	LAJUNTAW 115.00	1	LAJUNTAT 69.000-LAJUNTAT 115.00 CIRCUIT 1	40	128.3	2
BRADLEY 115.00	KELKER W 115.00	1	FOUNTAIN 115.00-RD_NIXON 115.00 CIRCUIT 1	159	103.5	1
BRIGHTNW 115.00	SANDCRK 115.00	1	BRIGHTNW 115.00-ERIE SW 115.00 CIRCUIT 1	220	105	1
BRUSHTAP 115.00	EFMORGTP 115.00	1	BRIGHTNW 115.00-ERIE SW 115.00 CIRCUIT 1	160	100.1	1
CANONCTY 69.000	CANONCTY 115.00	1	AREQUGCH 115.00-W CANON 115.00 CIRCUIT 1	56	116.2	2
CANONCTY 69.000	NCANON W 69.000	1	AREQUGCH 115.00-W CANON 115.00 CIRCUIT 1	32	146.8	2
COBBLKTP 115.00	TIMNTHTP 115.00	1	OWL_CRK 115.00-PONNEQUI 115.00 CIRCUIT 1	109	119.1	2
COLBRAN 115.00	COLBRAN 138.00	T2	CLIFTON 230.00-GRANDJCT 230.00 CIRCUIT 1	14	97.8	6
CTTNWD N 230.00	FULLER 230.00	1	E_DORADO 230.00-RD_NIXON 230.00 CIRCUIT 1	317	105.3	3
DEL CTAP 115.00	DELCAMIN 115.00	1	BEAVERCK 230.00-ERIE SW 230.00 CIRCUIT 1	130	104.7	3
DURANGO 115.00	HESPERUS 115.00	1	FLOR.RIV 115.00-HESPERUS 115.00 CIRCUIT 1	85	179.3	4
ELDORADO 115.00	PLAINVW 115.00	1	BO TERM 115.00-SUNSHTAP 115.00 CIRCUIT 1	17.4	123.2	1727

Case Name: *18hs1pPTI_CLRTPGr0*
as compared to: *18hs1p*

From Bus	To Bus	Circuit	Most Severe Contingency	Rating(MVA)	Max Percent	Count
FLOR.RIV 115.00	HESPERUS 115.00	1	BAYFIELD 115.00-DURANGO 115.00 CIRCUIT 1	128	179.5	1
FLYHORSE 115.00	KETTLECK 115.00	1	CTTNWD N 230.00-FULLER 230.00 CIRCUIT 1	139	141.4	6
FLYHORSE 115.00	MONUMENT 115.00	1	CTTNWD N 230.00-FULLER 230.00 CIRCUIT 1	139	153.3	9
FONTERO 115.00	RAMPART 115.00	1	CTTNWD N 230.00-FULLER 230.00 CIRCUIT 1	129	99	1
FOUNTAIN 115.00	RD_NIXON 115.00	1	CTTNWD N 230.00-FULLER 230.00 CIRCUIT 1	182	123.9	1663
HESPERUS 115.00	HESPERUS 345.00	2	HESPERUS 115.00-HESPERUS 345.00 CIRCUIT 1	250	96.5	1
HESPERUS 115.00	ROCKWOOD	1	NORWOOD 115.00-SUNSH SM 115.00 CIRCUIT 1	95	124.9	8
HOYT 115.00	SANDCRK 115.00	1	BRIGHTNW 115.00-ERIE SW 115.00 CIRCUIT 1	220	104.8	1
KIOWA CK 115.00	WIGGINS 115.00	1	BRIGHTNW 115.00-ERIE SW 115.00 CIRCUIT 1	60	164.8	4
LAGARITA 69.000	PLAZA 69.000	1	HOOPERTP 69.000-SANLSVLY 69.000 CIRCUIT 1	26.1	115.6	1
LAJUNTAW 69.000	LAJUNTAW 115.00	1	LAJUNTAT 69.000-LAJUNTAT 115.00 CIRCUIT 1	25	105.3	2
LAJUNTAW 69.000	LAJUNTAW 115.00	2	LAJUNTAT 69.000-LAJUNTAT 115.00 CIRCUIT 1	25	105.3	2
MIDWAYBR 115.00	RANCHO 115.00	1	FALCONMV 115.00-FULLER 115.00 CIRCUIT 1	77	97.3	1
MONTROSE 115.00	SOCANAL 115.00	1	CURECANT 230.00-LOSTCANY 230.00 CIRCUIT 1	120	110.1	3
MONUMENT 115.00	PALMER 115.00	1	MIDWAYPS 230.00-MIDWAYPS 345.00 CIRCUIT T1	134.8	106.2	11
NSS1 69.000	NSS2 69.000	1	NSS2 69.000-WYODAK 69.000 CIRCUIT 1	85	96	1
NSS2 69.000	WYODAK 69.000	1	NSS1 69.000-NSS2 69.000 CIRCUIT 1	85	95.9	1
SIDNEY 115.00	SIDNEY 230.00	1	N.YUMA 230.00-SPRNGCAN 230.00 CIRCUIT 1	167	113.4	12
SIDNEY 230.00	SIDNEYDC 230.00	1	AULT 345.00-LAR.RIVR 345.00 CIRCUIT 1	240	97.2	1
SMOKYHIL 115.00	SMOKYHIL 230.00	T1	SMOKYHIL 115.00-SMOKYHIL 230.00 CIRCUIT T2	150	96.1	1
WILOW CK 69.000	WILOW CK 115.00	1	WILOW CK 69.000-WILOW CK 115.00 CIRCUIT 2	42	112.8	1
WILOW CK 69.000	WILOW CK 115.00	2	WILOW CK 69.000-WILOW CK 115.00 CIRCUIT 1	42	112.8	1