System Unique Loading Report

Case Name: *18hs1p*
as compared to: *18hs1pPTI_CLRTPGr0*

From Bus	To Bus	Circuit	Most Severe Contingency	Rating(MVA)	Max Percent	Count
BELMONT 69.000	BLENDE 69.000	1	ASPEN TP 69.000-BLENDE 69.000 CIRCUIT 1	32	99.3	2
BMONT TP 69.000	OVERTON 69.000	1	ASPEN TP 69.000-BLENDE 69.000 CIRCUIT 1	48	105.3	2
BMONT TP 69.000	W.STATON 69.000	1	ASPEN TP 69.000-BLENDE 69.000 CIRCUIT 1	48	105.2	2
CAPHILL2 115.00	DENVTM 115.00	1	DENVTM 115.00-GRAY ST 115.00 CIRCUIT 1	131	96.4	1
COMANCHE 115.00	COMANCHE 230.00	A2	COMANCHE 115.00-COMANCHE 230.00 CIRCUIT A1	184	107	1
EMIGRANT 115.00	GERING 115.00	1	GERING 115.00-STEGALL 115.00 CIRCUIT 1	80	120.8	1
EMIGRANT 115.00	STEGALL 115.00	1	GERING 115.00-STEGALL 115.00 CIRCUIT 1	109	100.1	1
GERING 115.00	STEGALL 115.00	1	EMIGRANT 115.00-STEGALL 115.00 CIRCUIT 1	80	135	2
GRAN TAP 69.000	HOLL TAP 69.000	1	LAMAR CO 115.00-VILAS 115.00 CIRCUIT 1	55	101.5	2
GRAN TAP 69.000	WILOW CK 69.000	1	LAMAR CO 115.00-VILAS 115.00 CIRCUIT 1	55	112.8	2
HUGHES 69.000	WYODAK 69.000	1	WYODAK 69.000-WYODAK 230.00 CIRCUIT 2	75	97.6	1
HYDEPARK 115.00	PUEBPLNT 115.00	1	FREEMARY 115.00-READER 115.00 CIRCUIT 1	105	96.1	1
LAJUNTAT 69.000	LAJUNTAT 115.00	2	LAJUNTAT 69.000-LAJUNTAT 115.00 CIRCUIT 1	25	129.6	2
LANGE 69.000	LANGE 230.00	1	RCSOUTH1 230.00-RCSOUTH2 69.000 CIRCUIT 1	100	104.9	1
LANGE 69.000	LANGE 230.00	2	RCSOUTH1 230.00-RCSOUTH2 69.000 CIRCUIT 1	100	106	1
MIDWAYPS 115.00	MIDWAYPS 230.00	T1	APT MEM 115.00-APT PARK 115.00 CIRCUIT 1	100	99.7	1
P.VALLEY 115.00	TODD CRE 115.00	1	FTLUPTON 115.00-FTLUPTON 230.00 CIRCUIT T3	134.8	99	1
PONCHABR 230.00	W CANON 230.00	1	COMAN 3 24.000-COMANCHE 345.00 CIRCUIT 1	239	106.5	3
PUEB-TAP 115.00	STEM BCH 115.00	1	WALSENBG 115.00-WALSENBG 230.00 CIRCUIT 1	77	99.8	3
PUEB-TAP 115.00	W.STATON 115.00	1	WALSENBG 115.00-WALSENBG 230.00 CIRCUIT 1	95	117.8	1674
SANLSVLY 115.00	SANLSVLY 230.00	T1	SANLSVLY 115.00-SANLSVLY 230.00 CIRCUIT T2	150	111.8	1

Case Name: *18hs1p*
as compared to: *18hs1pPTI_CLRTPGr0*

From Bus	To Bus	Circuit	Most Severe Contingency	Rating(MVA)	Max Percent	Count
SANLSVLY 115.00	SANLSVLY 230.00	T2	SANLSVLY 115.00-SANLSVLY 230.00 CIRCUIT T1	150	111.8	1
SANLSVLY 69.000	SANLSVLY 115.00	T3	SANLSVLY 115.00-SARGENT 115.00 CIRCUIT 1	42	112.2	1
SANLSVLY 69.000	SANLSVLY 115.00	T4	SANLSVLY 115.00-SARGENT 115.00 CIRCUIT 1	42	112.2	1
SIDNEY 230.00	STEGALL 230.00	1	HOLCOMB 500.00-SANDSAGE 22.000 CIRCUIT 1	239	104.7	7
WALSENBG 115.00	WALSENBG 230.00	1	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	100	105.7	1
WYODAK 69.000	WYODAK 230.00	1	WYODAK 69.000-WYODAK 230.00 CIRCUIT 2	70	162.4	4
WYODAK 69.000	WYODAK 230.00	2	NSS2 13.800-NSS2 69.000 CIRCUIT 1	100	129.6	5