System Unique Voltage Report

Case Name: *18hs1p*
as compared to: *18hs1pPTI_CLRTPGr0*

Bus Name	Most Severe Contingency	Worst Case Voltage	Angle	Count
ARCHER 115.00	SYSTEM NORMAL	1.04462	41.9222	1
B.SANDY 230.00	SYSTEM NORMAL	1.04877	41.3082	1
BL_TAP 500.00	SYSTEM NORMAL	1.06435	44.1395	1
BSNDYSC1 500.00	SYSTEM NORMAL	1.05798	40.8491	1
BURLSC1 500.00	SYSTEM NORMAL	1.04587	41.1418	1
BURLSC2 500.00	SYSTEM NORMAL	1.05183	43.7115	1
BURROCYN 115.00	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.88627	13.9779	1
CHEN TAP 69.000	LAMAR CO 115.00-VILAS 115.00 CIRCUIT 1	0.66727	16.9689	3
CHENEY 69.000	LAMAR CO 115.00-VILAS 115.00 CIRCUIT 1	0.65526	15.844	4
EGYCNTR 230.00	SYSTEM NORMAL	1.05399	44.6286	1
EGYCNTR 500.00	SYSTEM NORMAL	1.05749	44.8047	1
ENNIS 115.00	FTLUPTON 115.00-FTLUPTON 230.00 CIRCUIT T3	0.89972	14.1938	1
FLEMING 115.00	MESSEX 115.00-STERLING 115.00 CIRCUIT 1	0.89292	26.8236	4
FORESTLK 115.00	EMIL AND 115.00-FORESTLK 115.00 CIRCUIT 1	1.10289	26.4008	1
FOWLER 69.000	BOONE 115.00-BOONE 230.00 CIRCUIT 1	0.89691	23.3374	1
FRENCHCK 115.00	FRENCHCK 115.00-WAUNETA 115.00 CIRCUIT 1	0.89855	28.2702	2
FT HOLLY 69.000	LAMAR CO 115.00-VILAS 115.00 CIRCUIT 1	0.76748	23.9114	4
FT. LYON 69.000	BOONE 115.00-BOONE 230.00 CIRCUIT 1	0.89914	23.3316	1
FTLUPTON 115.00	FTLUPTON 115.00-FTLUPTON 230.00 CIRCUIT T3	0.90451	14.7132	1
GILLETTE 69.000	WYODAK 69.000-WYODAK 230.00 CIRCUIT 2	0.8837	53.8913	2
GILLETTS 69.000	WYODAK 69.000-WYODAK 230.00 CIRCUIT 2	0.88389	53.9316	2

Case Name: *18hs1p*
as compared to: *18hs1pPTI_CLRTPGr0*

Bus Name	Most Severe Contingency	Worst Case Voltage	Angle	Count
GRAN TAP 69.000	GRAN TAP 69.000-WILOW CK 69.000 CIRCUIT 1	0.77968	16.8838	3
GRANADA 69.000	GRAN TAP 69.000-WILOW CK 69.000 CIRCUIT 1	0.77762	16.7188	3
HAXTUN 115.00	MESSEX 115.00-STERLING 115.00 CIRCUIT 1	0.89778	27.6909	3
HOLL TAP 69.000	LAMAR CO 115.00-VILAS 115.00 CIRCUIT 1	0.77306	24.367	4
HUDSON 115.00	FTLUPTON 115.00-FTLUPTON 230.00 CIRCUIT T3	0.9003	14.271	1
LAMAR CO 230.00	SYSTEM NORMAL	1.04923	44.4769	1
LAMAR DC 230.00	SYSTEM NORMAL	1.04916	44.4922	1
LAS_ANIM 500.00	SYSTEM NORMAL	1.06071	44.2961	1
LINCOLNT 230.00	SYSTEM NORMAL	1.04847	41.3631	1
LS ANMAS 69.000	BOONE 115.00-BOONE 230.00 CIRCUIT 1	0.90071	23.4676	1
LUDLOTAP 115.00	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.89903	17.8731	1
MCFT PR 69.000	OSAGE 69.000-OSAGE 230.00 CIRCUIT 1	0.89737	60.21	1
MESSEX 115.00	BEAVERCK 115.00-MESSEX 115.00 CIRCUIT 1	0.88962	25.5327	1
MIDWAY 500.00	SYSTEM NORMAL	1.07285	41.0642	1
ORDWAY 69.000	BOONE 115.00-BOONE 230.00 CIRCUIT 1	0.89457	23.1163	1
PINONCYN 115.00	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.89736	17.4503	1
PLAZA 69.000	PONCHABR 230.00-W CANON 230.00 CIRCUIT 1	0.89503	61.7656	3
PRINGLE 69.000	ANGOSTUR 69.000-WESTHILL 69.000 CIRCUIT 1	0.89347	42.7519	1
PUEB W 115.00	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.82551	14.0332	1
PUEB-TAP 115.00	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.82747	14.4089	1
SANLSVLY 115.00	SYSTEM NORMAL	1.04461	55.6962	1
STEM BCH 115.00	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.84661	16.3174	1
STMBEACH 69.000	PUEB-TAP 115.00-W.STATON 115.00 CIRCUIT 1	0.85088	17.1223	1

Case Name: *18hs1p*
as compared to: *18hs1pPTI_CLRTPGr0*

Bus Name		Most Severe Contingency			Worst Case Voltage	Angle	Count
VERNONLM	115.00	WRAY	115.00-WRAY	230.00 CIRCUIT 1	0.90485	32.8397	1
WALSENBG	69.000	WALSENBG	69.000-WALSENBG	115.00 CIRCUIT 1	0.75523	19.0199	2