

“On December 11, 2006 the Mead Phoenix Project E&O Committee approved a rating change proposed by Western for the Mead to Marketplace 500kV Transmission Line. The change in rating was allowed due to the recent redefinition of Path 63 through the WECC Three Phase Path Rating Process. Path 63 was redefined to include only the Mead to Perkins 500kV Transmission Line. The Mead to Marketplace 500kV Transmission Line is no longer included in the definition of Path 63. The Mead to Marketplace 500kV Transmission Line is now an internal line in the Western Control Area. Based on study work done by Western, which was coordinated with Mead Phoenix Project Participants and Nevada Power Company, the rating of the Mead to Marketplace 500kV Transmission Line will be increased from 1852 MW to 2600 MW beginning February 1, 2007. The new rating will apply bi-directionally.

On January 18, 2007, at 0900 MST, the TTC on the Mead to Marketplace 500kV Transmission Line will be increased effective February 1, 2007.